

Big Sandy Plant Fly Ash Pond

Notice of Appendix IV Constituents Detected at Statistically Significant Levels
above the Groundwater Protection Standard

As required by 40 CFR 257.95(g) and 40 CFR 257.105(h)(8), this is a notification to the Big Sandy plant's operating record that on February 3, 2021 beryllium, cobalt, and lithium were detected at statistically significant levels above the groundwater protection standard in one monitoring well.