

SAFETY FACTOR ASSESSMENT INITIAL ASSESSMENT

CFR § 257.74(e)

East Bottom Ash Pond

Rockport Plant
Rockport, Indiana

October, 2023

Prepared for: Indiana Michigan Power Company

Prepared by: Worley
One Meridian Boulevard
Suite 2C02, Wyomissing, PA, 19610




**SAFETY FACTOR ASSESSMENT
INITIAL ASSESSMENT
CFR § 257.74(E)
ROCKPORT PLANT
EAST BOTTOM ASH POND**

PREPARED BY _____ DATE _____
Yingwu Xu, P.E.

REVIEWED BY _____ DATE _____
Erik Leiby

APPROVED BY _____ DATE _____
Greg Nadeau, P.E.



I certify to the best of my knowledge, information, and belief that the information contained in this safety factor assessment meets the requirements of 40 CFR § 257.74(e)

Table of Contents

1.0	Introduction.....	4
2.0	Description of the CCR Unit.....	4
3.0	Subsurface Conditions	5
3.1	Site Geology.....	5
3.2	Review of Historical Soil Borings.....	5
4.0	Geotechnical Analysis	5
4.1	Strength Parameters	6
4.2	Phreatic Surface & Pond Levels	6
4.3	Groundwater Condition	6
4.4	Load Cases Analyzed	7
4.5	Liquefaction Considerations	8
5.0	Results.....	8
6.0	Conclusions.....	10

List of Appendices

- Appendix A: Site Plans and Cross Section Locations
- Appendix B: Slope Stability Analysis Outputs
- Appendix C: Historical Soil Borings & Geotechnical Data
- Appendix D: Original Design Drawings

List of Tables:

- Table 1: Engineering Properties used in Safety Factor Assessment
- Table 2: Load Cases Analyzed for the North-to-South Splitter Dike
- Table 3: Load Cases Analyzed for the East to West Splitter Dike
- Table 4: Safety Factor Assessment Summary for the North to South Splitter Dike
- Table 5: Safety Factor Assessment Summary for the East to West Splitter Dike

1.0 Introduction

This report was prepared by Worley to fulfill requirements of 40 CFR §257.74(e) for the initial safety factor assessment of the East Bottom Ash Pond (EBAP) following the completion of a retrofit.

2.0 Description of the CCR Unit

The Rockport plant is located near the City of Rockport, Spencer County, Indiana. It is owned by Indiana Michigan Power Co. (I&M), a unit of American Electric Power. The facility operates one active surface impoundment (East Bottom Ash Pond) for storing CCR waste within the bottom ash complex. There are six main ponds within the bottom ash pond complex as listed below.

- East Bottom Ash Pond
- West Bottom Ash Pond (To commence closure October, 2023)
- East Waste Water Pond
- West Waste Water Pond
- Reclaim Pond
- Clear Water Pond

Following retrofit, the East Bottom Ash Pond is lined with a textured 40-mil LLDPE geomembrane overtop a geosynthetic clay liner (GCL) overtop a 10 oz/sy non-woven geotextile and discharges to the East Waste Water Pond. The West Bottom Ash Pond will commence closure when the retrofitted East Bottom Ash Pond goes into service.

The East Bottom Ash Pond is incised on the northern and eastern sides of the pond and contains an east-to-west forebay dike at elevation 394. A north-to-south trending splitter dike separates the East Bottom Ash Pond from the West Bottom Ash Pond. An east-to-west trending splitter dike separates the East Bottom Ash Pond from the East Waste Water Pond.

The north-to-south trending splitter dike between the East Bottom Ash Pond and West Bottom Ash Pond is approximately 2,000 feet long. The design height of the splitter dike is 18 feet (El. 399 to 381). The dike is constructed out of compacted soil. Both interior and exterior slopes are designed to be 2 horizontal to 1 vertical. Native soil is estimated around elevation 390, based on original design drawings.

The east-to-west trending splitter dike between the East Bottom Ash Pond and the East Waste Water Pond is approximately 650 feet long. The maximum design height is 20.5 feet measured from the top of the dike to the bottom of the East Waste Water Pond (El. 399 to 378.5). The dike is constructed out of compacted soil. Both interior and exterior slopes are designed to be 2 Horizontal to 1 Vertical. Native soil is estimated around elevation 390, based on original design drawings.

The east-to-west forebay dike within the East Bottom Ash Pond is approximately 650 feet long. The maximum design height is 15.5 feet measured from the top of the dike to the toe of the slope at the forebay (El. 394 to 378.5). The dike is constructed out of compacted cohesive soils. Both interior and exterior slopes are designed to be 2 horizontal to 1 vertical.

3.0 Subsurface Conditions

3.1 Site Geology

The site of Rockport bottom ash pond complex is within the flood plain of the Ohio River and the Boonville Hills physiographic province of the Southern Hills and Lowlands physiographic region.

According to the USDA Soil Survey of Spencer County, Indiana (September 2015), the predominant soil in the vicinity of the site is the Ginat silt loam (Gn). The Weinbach silt loam (WcA), Sciotoville silt loam (ScA and ScB2), and Wheeling loam (WhB2) are also present near the facility, but to a lesser extent. A majority of the soils in the vicinity of the site have been altered or removed during site development and are classified as Udorthents (Uaa) or Mine Dumps (Du).

The Ginat consists of poorly-drained silt loam and silty clay loam. The Weinbach consists of somewhat poorly drained silt loam and silty clay loam. The Sciotoville and Wheeling consist of moderately well-drained to well-drained silt loam, clay loam, and loam.

The bottom ash pond complex is located on the western bank of the Ohio River and is underlain by Quaternary age alluvium consisting of Wisconsinan age undifferentiated outwash. Geotechnical borings performed at the site during the original subsurface investigation indicate clay generally ranging from less than 5 to about 15 feet in thickness, but may extend up to about 30 feet and contain layers or lenses of fine sand. The clay layer was underlain by fine to coarse sand deposits. Historical boring information is presented in Appendix C.

Bedrock consists of the Raccoon Creek Group Formation of Pennsylvanian age and is comprised of predominantly shale and sandstone with thin beds of limestone, clay, and coal. The Raccoon Creek Group is underlain by rocks ranging in age from Middle Devonian to Late Mississippian and is located at about elevation 280 to 300 feet.

Structurally, the area is located within the Illinois Basin, near the eastern border of the Wabash Valley Seismic Zone, which generally consists of vertically-oriented faults buried under layers of sediment.

3.2 Review of Historical Soil Borings

A review of historical borings information was performed to develop a soil profile and define soil shear strength properties. Relevant historical geotechnical borings and laboratory testing data is included in Appendix C of this report. In 2016, Terracon performed two soil borings through the western dike of the West Bottom Ash Pond.

In addition, soil boring logs for monitoring wells 1604, 1605, and 1606 were also used to develop a soil profile. The top of natural soil horizon is based on the original construction-grading plan for the Bottom Ash Ponds.

4.0 Geotechnical Analysis

Slope stability analysis was performed using Slide 6.0 developed by Rocscience Inc. This program is based on the principles of limit equilibrium analysis. The GLE/Morgenstern-Price Method was used to solve 2-Dimension Limit Equilibrium equations.

Seismic loading was performed using a horizontal seismic coefficient of 0.145. The seismic coefficient considers ½ of the 2008 Peak Ground Acceleration with 2% Probability of Exceedance in 50 Years for firm

rock (0.22), with an amplification factor of 1.32. This seismic coefficient is consistent with seismic loading parameters from Terracon’s 2016 Safety Factor Assessment report.

Rapid drawdown scenarios were modeled due to adjacent pond operations for the splitter dikes. The Duncan, Wright, and Wong (1990) method was used to define the shear strength properties of soils subjected to drawdowns. Total stress shear strength properties are applied to soils that would be subjected to drawdowns.

4.1 Strength Parameters

Strength parameters were developed based on the results of the field and laboratory testing. Soil profiles were developed based on subsurface conditions interpreted from the borings. Table 1 summarizes the engineering properties used in the Safety Factor Assessment. Shear strength parameters assigned to the soil profile were based on the Standard Penetration Test n-Values and the consolidated-undrained Triaxial compression tests performed by Terracon in 2016 in nearby boring locations.

Table 1: Engineering Properties used in Safety Factor Assessment					
Material	Unit Weight (pcf)	Effective Stress Parameters		Total Stress Parameters	
		Φ' (degree)	C' (psf)	Φ (degree)	C (psf)
Embankment Fill	130	29	50	19	400
Foundation Clay	123	34	50	22	200
Loose Sand	115	30	0		
Medium Dense Sand	123	33	0		

4.2 Phreatic Surface & Pond Levels

The phreatic surface modeled in the Safety Factor Assessment assumes a simple straight line through the dike cross section. The author believes this is a slightly conservative assumption, but is relevant given the absence of piezometers within the embankment dikes.

The pool elevation for the East Bottom Ash Pond for both maximum storage pool loading condition and the maximum surcharge pool loading condition is 396’ since the East Bottom Ash Pond does not receive stormwater inflow from the adjacent areas. It is worth noting that since the Retrofit of the East Bottom Ash Pond is lined, the pond does not recharge and connect to the phreatic surface outside of the pond. The maximum operating pool for the East Waste Water Pond of 389’ as modeled is based on original design drawing (AEP Drawing 12-30027-8).

4.3 Groundwater Condition

Based on the Groundwater Monitoring Network Evaluation, the principal groundwater flow zone underlying the ponds is the lower overburden unit consisting of granular outwash deposits (poorly sorted sand with interlayered sand and gravel). Recharge into this unit occurs laterally from hills and buried tributary valleys to the north-northwest. Recharge also occurs from the Ohio River to the southeast during relatively brief periods (spikes) of high water level in the Ohio river. Areal recharge also occurs vertically from the surface. Artificial recharge can also occur from units containing standing surface water, such as the waste water ponds but not the East Bottom Ash Pond which is lined, depending on the hydraulic separation provided by natural materials and engineered soil lining the bottoms of these units.

The hydrostratigraphic unit identified as the uppermost aquifer is the saturated granular outwash deposit that underlies the Rockport Plant property including the Bottom Ash Ponds. The top of this unit would be the typical seasonal high water level of 373.5 feet, 25.5 feet below the crest elevation of the pond embankments (399 feet).

The safety factor assessments consider a groundwater level of 373.5 feet and artificial recharge from the ponds.

4.4 Load Cases Analyzed

4.4.1 North to South Splitter Dike

The north-to-south splitter dike separates the East Bottom Ash Pond from the West Bottom Ash Pond.

Per 40 CFR 257.73(e)(1), the safety factor assessments were performed for the following conditions: (i) end of construction loading condition; (ii) long-term, maximum storage pool loading condition; (iii) maximum surcharge pool loading condition; (iv) seismic condition. As demonstrated in Section 4.5, since dike fill materials are not subject to liquefaction, no further assessment was required.

Since the East Bottom Ash Pond does not receive stormwater inflow from the adjacent areas, both maximum storage pool loading condition and the maximum surcharge pool loading condition can be combined.

Additionally, rapid drawdown was performed for the downstream slope of the East Bottom Ash Pond and the West Bottom Ash Pond.

The load cases analyzed for the north-to-south splitter dike are summarized in Table 2.

Scenario Description	West Bottom Ash Pond Pool Elevation	East Bottom Ash Pond Pool Elevation	Commentary
257.74(e)(1)(i) End-of-Construction Loading Condition	390	378.5	WBAP at the existing condition; EBAP drained
257.74(e)(1)(ii) Long Term, Maximum Storage Pool Loading Condition 257.74(e)(1)(iii) Maximum Surcharge Pool Loading Condition	390	396	WBAP cleaned out and Closed at El. 385'; EBAP in max pool elevation
257.74(e)(1)(iv) Seismic	390	378.5	WBAP Cleaned out and Closed at El. 385'; EBAP drained
Rapid Drawdown of WBAP	390 to 386	396	WBAP drained for cleaning out; EBAP in max pool elevation

4.4.2 East to West Splitter Dike

The east to west splitter dike separates the East Bottom Ash Pond from the East Waste water Pond. Similar to the north-to-south splitter dike, the load cases analyzed for the east-to-west splitter dike are summarized in Table 3

Scenario Description	East Waste water Pond Water Surface Elevation	East Bottom Ash Pond Water Surface Elevation	Commentary
257.74(e)(1)(i) End-of-Construction Loading Condition	389	378.5	EWWP in service; EBAP Drained
257.74(e)(1)(ii) Long Term, Maximum Storage Pool Loading Condition 257.74(e)(1)(iii) Maximum Surcharge Pool Loading Condition	389	396	EWWP in service; EBAP in max pool elevation
257.74(e)(1)(iv) Seismic	389	378.5	EWWP in service; EBAP drained
Rapid Drawdown of EWWP	389 to 375	396	EWWP drained; EBAP in max pool elevation

4.5 Liquefaction Considerations

In addition, the CCR rules require that for dikes constructed of soils with a susceptibility to liquefaction, the calculated factor of safety against liquefaction must equal or exceed a value of 1.20. The splitter dikes are constructed predominantly of lean clay containing varying amounts of sand and is not considered to be susceptible to liquefaction.

5.0 Results

The results of the Safety Factor Assessment are summarized in Table 4 for the North to South Splitter Dike and Table 5 for the East to West Splitter Dike. The outputs of the slope stability analyses are contained in Appendix B of this report.

Table 4: Safety Factor Assessment Summary for the North to South Splitter Dike

Scenario Description	Calculated Factor of Safety	Required Factor of Safety	Acceptable (Yes or No)	Commentary
257.74(e)(1)(i) End-of-Construction Loading Condition	1.94	1.30	Yes	
257.74(e)(1)(ii) Long Term, Maximum Storage Pool Loading Condition 257.74(e)(1)(iii) Maximum Surcharge Pool Loading Condition	1.69	1.50 and 1.40	Yes	
257.74(e)(1)(iv) Seismic	1.43	1.00	Yes	Horizontal seismic coefficient = 0.145
257.74(e)(1)(v) Liquefaction	Not Applicable	1.20		
Rapid Drawdown of West Bottom Ash Pond	2.19	*		*= Required Factor of Safety not specified in 40 CFR 257.74(d)(1)(vii).

Table 5: Safety Factor Assessment Summary for the East to West Splitter Dike

Scenario Description	Calculated Factor of Safety	Required Factor of Safety	Acceptable (Yes or No)	Commentary
257.74(e)(1)(i) End-of-Construction Loading Condition	1.82	1.30	Yes	
257.74(e)(1)(ii) Long Term, Maximum Storage Pool Loading Condition 257.74(e)(1)(iii) Maximum Surcharge Pool Loading Condition	1.53	1.50 and 1.40	Yes	
257.74(e)(1)(iv) Seismic	1.34	1.00	Yes	Horizontal seismic coefficient = 0.145
257.74(e)(1)(v) Liquefaction	Not Applicable	1.20		
Rapid Drawdown of EWWP	1.51	*	Yes	*= Required Factor of Safety not specified in 40 CFR 257.74(d)(1)(vii).

6.0 Conclusions

Based on the analysis presented in this report, the splitter dikes that impound the East Bottom Ash Pond at the Rockport Plant meet the required factors of safety as required by 40 CFR §257.74(e)(1)(i) through (v) for all load cases considered.

Appendix A- Site Plans and Cross Section Locations

12-301203

GENERAL NOTES

- BACKGROUND LAND SURFACE TOPOGRAPHY AND FEATURES ARE FROM A SURVEY BY PRECISION SURVEYING, INC. DATED 02-08-21. HORIZONTAL AND VERTICAL DATUM BASED ON AEP ROCKPORT SITE CONTROL SYSTEM.
- COORDINATE GRID SHOWN IS SITE COORDINATE SYSTEM. FOR SITE MONUMENTATION SEE DRAWING 12-300418.

WEST BOTTOM ASH POND

RETROFITTED EAST POND

REVESTMENT LINED FOREBAY

METAL CLEANING

WASTE BASIN

LEGEND:

- EXISTING GRADE CONTOUR
- EXISTING PIPE
- TOP POND SIDE SLOPE
- TOE
- EXISTING ELECTRIC MANHOLE
- EXISTING PIPE BOLLARD
- EXISTING WATER VALVE
- LIMIT OF LINER SYSTEM
- NEW LINER ANCHOR TRENCH

SEE WORLEY REVISION BLOCK

DATE	NO.	DESCRIPTION	APP'D.
REVISIONS			

THIS DRAWING IS CLASSIFIED AS:

AEP CONFIDENTIAL

REFERENCE AEP'S CORPORATE INFORMATION SECURITY POLICY

THIS DRAWING IS THE PROPERTY OF THE AMERICAN ELECTRIC POWER SERVICE CORP. AND IS LOANED UPON CONDITION THAT IT IS NOT TO BE REPRODUCED OR COPIED, IN WHOLE OR IN PART, OR USED FOR FURNISHING INFORMATION TO ANY PERSON WITHOUT THE WRITTEN CONSENT OF THE AEP SERVICE CORP. OR FOR ANY PURPOSE DETRIMENTAL TO THEIR INTEREST, AND IS TO BE RETURNED UPON REQUEST.

INDIANA MICHIGAN POWER COMPANY
ROCKPORT PLANT


ROCKPORT INDIANA
CORVIE/G PROJECT

**EAST BOTTOM ASH POND
SAFETY FACTOR ASSESSMENT
CROSS SECTION LOCATIONS**

UNIT:	DRAWING NUMBER:	REV:
SCALE: 1"=60'	Sketch 1	
DR:	CIVIL ENGINEERING	
CH:		
SUP:	DOCUMENT PREPARED BY	
ENG:	WORLEY	
DATE:		

AMERICAN ELECTRIC POWER

AEP SERVICE CORP.
1 RIVERSIDE PLAZA
COLUMBUS, OH 43215



CROSS REFS:

CROSS REFS:

CROSS REFS:

12-301203


GENERAL NOTES

- BACKGROUND LAND SURFACE TOPOGRAPHY AND FEATURES ARE FROM A SURVEY BY PRECISION SURVEYING, INC. DATED 02-08-21. HORIZONTAL AND VERTICAL DATUM BASED ON AEP ROCKPORT SITE CONTROL SYSTEM.
- COORDINATE GRID SHOWN IS SITE COORDINATE SYSTEM. FOR SITE MONUMENTATION SEE DRAWING 12-300418.
- CONTRACTOR TO PLACE FILL MATERIALS IN EXISTING EAST BOTTOM ASH POND (EXCAVATED AND HAULED FROM ON-SITE BORROW AREA) TO ESTABLISH PREPARED LINER SYSTEM SUBGRADE, AS INDICATED ON LINER DETAILS (OPTION 1) ON REF. DWG 12-301205.
- FOR LINER SYSTEM SUBGRADE ELEVATIONS SEE DRAWING 12-301203A.
- INSTALL 25 GAS FLAP VENTS AROUND BOTTOM ASH POND (5 ON SOUTH SIDE, 10 ON EAST SIDE, AND 10 ON WEST SIDE).
- INSTALL 7 GAS RISER VENTS AROUND POND FOREBAY AREA (3 ON NORTH SIDE, 2 ON EAST SIDE, AND 2 ON WEST SIDE).
- ALL WORK SHALL BE PERFORMED IN ACCORDANCE WITH A SEQUENCE AND WORK PLAN SUBMITTED BY THE CONTRACTOR AND ACCEPTED BY THE OWNER AND ENGINEER.
- WORK SHALL NOT BEGIN UNTIL ALL EXISTING EAST BOTTOM ASH POND INFLOWS/OUTFLOWS ARE DIVERTED OR PERMANENTLY PLUGGED.
- POND LINER SYSTEM SHALL BE ATTACHED TO ALL EXISTING POND STRUCTURES, PIPES, ETC. TO ASSURE NO AREAS OF LEAKING EXIST FOR THE INSTALLED LINER SYSTEM. TYPICAL LINER CONNECTION DETAILS AREA INDICATED ON REF. DWG'S 12-301205 AND 12-301206.
- MAINTAIN ACCESS TO AND PROTECT ALL EXISTING MONITORING WELLS DURING THE WORK. MAINTAIN A MINIMUM 10 FOOT BUFFER AROUND ANY WELL (NO EARTH DISTURBANCE) WHEN POSSIBLE. IF 10 FOOT BUFFER IS NOT POSSIBLE, GET DOCUMENTED APPROVAL FROM AEP ENVIRONMENTAL SERVICES ON ACCEPTABLE BUFFER, IF SHORING IS REQUIRED, OR ANY OTHER REQUIRED WELL PROTECTION CRITERIA, PRIOR TO THE WORK.
- REFER TO AND COMPLY WITH THE FOLLOWING AEP SPECIFICATIONS UNLESS INDICATED OTHERWISE ON DRAWINGS:
 - CE-004 EXCAVATION
 - CE-006 FILL
 - CE-006A EARTHWORK (BACKFILL) TESTING
 - CE-008 SUBSURFACE DRAINAGE SYSTEMS
 - CE-013A NON-WOVEN GEOTEXTILES
 - CE-018 SURVEY SERVICES
 - CE-021 AERIAL PHOTOGRAPHY AND TOPOGRAPHIC MAPPING
 - CE-026LL GEOMEMBRANE (LLDPE)
 - CE-035 GEOSYNTHETIC CLAY LINER
 - CE-036 DEMOLITION REMOVALS AND ALTERATIONS
 - CE-037 EXCAVATION AND BACKFILL FOR UNDERGROUND UTILITIES
 - CE-038 FLOWABLE BACKFILL (CONTROLLED LOW-STRENGTH MATERIAL)
 - CE-040 MATERIALS FOR UNDERGROUND PIPING AND SEWERS
 - CE-042 INSTALLATION OF UNDERGROUND HOPE PRESSURE PIPING
- ENSURE PIPES ARE OUT OF THE WAY FOR CCR REMOVAL FOR WEST BOTTOM ASH POND OR CCR MATERIAL IS REMOVED PRIOR TO PLACING PIPES.

WEST BOTTOM ASH POND

LINED EAST BOTTOM ASH POND

REVEMENT LINED FOREBAY




LEGEND:

- EXISTING GRADE CONTOUR
- EXISTING PIPE
- TOP POND SIDE SLOPE
- TOE
- EXISTING ELECTRIC MANHOLE
- EXISTING PIPE BOLLARD
- EXISTING WATER VALVE
- LIMIT OF LINER SYSTEM
- NEW LINER ANCHOR TRENCH

REFERENCE DRAWINGS

NO.	DATE	DESCRIPTION	BY	CHECKED	APPROVED
12-300418		UNITS 1 AND 2 SURVEY CONTROL AND MONUMENTATION PLAN			
12-301203A		EAST BOTTOM ASH POND LINER SUBGRADE PLAN			
12-301204		EAST BOTTOM ASH POND LINER SYSTEM SECTIONS AND DETAILS			
12-301205		EAST BOTTOM ASH POND LINER SYSTEM SECTIONS AND DETAILS			
12-301206		EAST BOTTOM ASH POND LINER SYSTEM SECTIONS AND DETAILS			
12-301215		EAST BOTTOM ASH POND BORROW AREA CIVIL SITE PLAN			
12-301220		POND COMPLEX EROSION AND SEDIMENT CONTROL PLAN			
12-30027		UNIT No. 1 & 2 WASTEWATER & BOTTOM ASH POND AREA SECTIONS & DETAILS			
12-5123		YARD PIPING UNIT No. 1 & 2 SHEET No. 2 OF 39			



PRELIMINARY STATUS	DATE	INFORMATION ONLY - NOT TO BE USED FOR CONSTRUCTION
APPROVED STATUS	DATE	REPRESENTS REVIEWED AND APPROVED DESIGN. ANY PORTION MARKED "HOLD UP" RETAINS PRELIMINARY STATUS.
DATE	31-MAR-22	
ORIGINATING PERSONNEL		PROFESSIONAL ENGINEER'S SEAL
DRAWN BY	KPF	
CHECKED BY	RE STOUT	
LEAD DESIGNER	KJ FRITZ	
ENGINEER/TECH SPECIALIST	ED LEIBY	
PROJECT ENGINEERING MANAGER	MH NACEY	



DATE	NO.	DESCRIPTION	APP'D.
		SEE WORLEY REVISION BLOCK	

THIS DRAWING IS CLASSIFIED AS:

AEP CONFIDENTIAL

REFERENCE AEP's CORPORATE INFORMATION SECURITY POLICY

THIS DRAWING IS THE PROPERTY OF THE AMERICAN ELECTRIC POWER SERVICE CORP. AND IS LOANED ON CONDITION THAT IT IS NOT TO BE REPRODUCED OR COPIED, IN WHOLE OR IN PART, OR USED FOR FURNISHING INFORMATION TO ANY PERSON WITHOUT THE WRITTEN CONSENT OF THE AEP SERVICE CORP. OR FOR ANY PURPOSE DETRIMENTAL TO THEIR INTEREST, AND IS TO BE RETURNED UPON REQUEST.

INDIANA MICHIGAN POWER COMPANY

ROCKPORT PLANT

ROCKPORT INDIANA

CRV/ELG PROJECT

EAST BOTTOM ASH POND LINER SYSTEM PLAN

UNIT: 12 DRAWING NUMBER: 301203 REV: 2

SCALE: 1"=60' CIVIL ENGINEERING

DOCUMENT PREPARED BY WORLEY


AEP SERVICE CORP. 1 RIVERSIDE PLAZA COLUMBUS, OH 43215

CROSS REFS:


#02100-21
30000 04/08/2023

GENERAL NOTES


1. THE EXPECTED POND BOTTOM ELEVATION AFTER CLOSURE BY REMOVAL IS EL. 376.0 (12-INCHES BELOW ORIGINAL POND BOTTOM), HOWEVER, IF THE CCR CLOSURE BY REMOVAL EXCAVATION/VERIFICATION PROCESS EXTENDS BELOW EL. 376.0, THEN ADDITIONAL FILL MATERIAL WILL BE REQUIRED, ACCORDINGLY, TO REACH THE NEW LINER SYSTEM SUBGRADE ELEVATION.
2. LINER SYSTEM SUBGRADE (EL. 378.5 AT LOWEST POINT) PROVIDES FOR THE BOTTOM OF THE POND LINER SYSTEM TO BE MINIMUM 5-FOOT SEPARATION FROM THE UPPERMOST AQUIFER AT EL. 373.5.



SECTION G3-G3 12-301203
SCALE: 1"=60' HORIZ
1"=20' VERT




SECTION D5-D5 12-301203
SCALE: 1"=60' HORIZ
1"=20' VERT



NOTE: RESTORE SURFACING TO MATCH EXISTING CONDITIONS WHEN PIPES ARE OUTSIDE NEWLY SURFACED AREAS.

TYPICAL PIPE TRENCH DETAIL
NOT TO SCALE



REFERENCE DRAWINGS

- 12-301203 EAST BOTTOM ASH POND LINER SYSTEM PLAN
- 12-301205 EAST BOTTOM ASH POND LINER SYSTEM SECTIONS AND DETAILS

SEE WORLEY REVISION BLOCK

DATE	DESCRIPTION	APP'D
REVISIONS		

THIS DRAWING IS CLASSIFIED AS:

AEP CONFIDENTIAL

REFERENCE AEP's CORPORATE INFORMATION SECURITY POLICY
THIS DRAWING IS THE PROPERTY OF THE AMERICAN ELECTRIC POWER SERVICE CORP. AND IS LOANED UPON CONDITION THAT IT IS NOT TO BE REPRODUCED OR COPIED, IN WHOLE OR IN PART, OR USED FOR FURNISHING INFORMATION TO ANY PERSON WITHOUT THE WRITTEN CONSENT OF THE AEP SERVICE CORP. OR FOR ANY PURPOSE DETRIMENTAL TO THEIR INTEREST, AND IS TO BE RETURNED UPON REQUEST.

INDIANA MICHIGAN POWER COMPANY
ROCKPORT PLANT
ROCKPORT INDIANA
CORVIE/G PROJECT

EAST BOTTOM ASH POND LINER SYSTEM SECTIONS AND DETAILS

UNIT: 12
DRAWING NUMBER: 301204
SCALE: AS NOTED
CIVIL ENGINEERING
REV: 1

DOCUMENT PREPARED BY WORLEY


AEP SERVICE CORP.
1 RIVERSIDE PLAZA
COLUMBUS, OH 43215



PRELIMINARY STATUS	DATE	INFORMATION ONLY - NOT TO BE USED FOR CONSTRUCTION.
APPROVED STATUS	DATE	REPRESENTS REVIEWED AND APPROVED DESIGN. ANY PORTION MARKED "HOLD" RETAINS PRELIMINARY STATUS.
ORIGINATING PERSONNEL		PROFESSIONAL ENGINEER'S SEAL

DRAWN BY: KPF
 CHECKED BY: RE STOUDT
 LEAD DESIGNER: KJ FRITZ
 ENGINEER/TECH SPECIALIST: ED LEIBY
 PROJECT ENGINEERING MANAGER: MH NACEY




Yingwu Xu
 REGISTERED PROFESSIONAL ENGINEER
 No. 12000238
 STATE OF OHIO
 2023.06.08.14
 17-55-04'00"



REV	DATE	DESCRIPTION	BY	CHECKED	REVIEWED	DESIGNED	DRAWN	INSTRUMENTED	QUALITY CONTROL	APPROVED
1	08 JUN 22	ISSUED FOR CONSTRUCTION; REVISED AS INDICATED	RES	KJF	EDL	KJF	EDL	EDL	EDL	MHN
0	31 MAR 22	ISSUED FOR CONSTRUCTION	KPF	RES	EDL	KJF	EDL	EDL	EDL	MHN

502100-21
3/23/2023 09:00:00



GENERAL NOTES



- NOTES:
1. LINER SHEETS SHALL BE TACK-WELDED TOGETHER AT OVERLAP TO FORM TEMPORARY BOND PRIOR TO WELDING.
 2. GRINDING NOT TO EXCEED 1/8" PAST "SQUEEZE-OUT" ON EITHER SIDE. PROPER CARE SHOULD BE TAKEN IN NOT REMOVING TOO MUCH MATERIAL WHEN GRINDING.
 3. VACUUM TESTING SHALL BE THE NON-DESTRUCTIVE SEAM TEST METHOD FOR EXTRUSION WELDS.

REFERENCE DRAWINGS

12-301203	EAST BOTTOM ASH POND LINER SYSTEM PLAN
12-301203A	EAST BOTTOM ASH POND LINER SUBGRADE PLAN



REV	DATE	DESCRIPTION	BY	CHECKED	REVIEWED	DESIGNED	DRAWN	INSTRUMENTED	QUALIFIED	REGISTERED
1	08 JUN 22	ISSUED FOR CONSTRUCTION; REVISED AS INDICATED	RES	KJF	EDL	KJF	EDL	EDL	EDL	MHN
0	31 MAR 22	ISSUED FOR CONSTRUCTION	KPF	RES	EDL	KJF	EDL	EDL	EDL	MHN

Worley
energy | chemicals | resources

oneWay
CONSTRUCTION SOFTWARE

PRELIMINARY STATUS DATE INFORMATION ONLY - NOT TO BE USED FOR CONSTRUCTION

APPROVED STATUS DATE REPRESENTS REVIEWED AND APPROVED DESIGN. ANY PORTION MARKED "HOLD" RETAINS PRELIMINARY STATUS.

LDE ED LEIBY 31-MAR-22

ORIGINATING PERSONNEL PROFESSIONAL ENGINEER'S SEAL

DRAWN BY KPF

CHECKED BY RE STOUDT

LEAD DESIGNER KJ FRITZ

ENGINEER/TECH SPECIALIST ED LEIBY

PROJECT ENGINEERING MANAGER MH NACEY

Yingwu Xu 2023 06 08 14:18:40 -04'00'

REGISTERED PROFESSIONAL ENGINEER
STATE OF INDIANA
No. 12000238

SEE WORLEY REVISION BLOCK

DATE	NO.	DESCRIPTION	APP'D.
REVISIONS			

THIS DRAWING IS CLASSIFIED AS:

AEP CONFIDENTIAL

REFERENCE AEP's CORPORATE INFORMATION SECURITY POLICY

THIS DRAWING IS THE PROPERTY OF THE AMERICAN ELECTRIC POWER SERVICE CORP. AND IS LOANED UPON CONDITION THAT IT IS NOT TO BE REPRODUCED OR COPIED, IN WHOLE OR IN PART, OR USED FOR FURNISHING INFORMATION TO ANY PERSON WITHOUT THE WRITTEN CONSENT OF THE AEP SERVICE CORP. OR FOR ANY PURPOSE DETRIMENTAL TO THEIR INTEREST, AND IS TO BE RETURNED UPON REQUEST.

INDIANA MICHIGAN POWER COMPANY

ROCKPORT PLANT

ROCKPORT INDIANA

CCR/ELG PROJECT

EAST BOTTOM ASH POND LINER SYSTEM SECTIONS AND DETAILS

UNIT: 12
DRAWING NUMBER: 301205
REV: 1

SCALE: NONE
CIVIL ENGINEERING

DOCUMENT PREPARED BY WORLEY

AEP SERVICE CORP.
1 RIVERSIDE PLAZA
COLUMBUS, OH 43215


CROSS REFS.

CROSS REFS.


CROSS REFS.

CROSS REFS.


Appendix B- Slope Stability Analysis Outputs



	Project		
	AEP Rockport East Bottom Ash Pond		
	Analysis Description		
	North-to-South Splitter Dike - End of Construction		
Drawn By	Scale	Company	
	1:282		
Date	File Name		
	NS Dike - EOC.slim		




	Project		
	AEP Rockport East Bottom Ash Pond		
	Analysis Description		
	North-to-South Splitter Dike - Max Pool		
Drawn By	Scale	Company	
	1:262		
Date	File Name		
	NS Dike - Max Pool.slim		




Property	Embankment Fill	Foundation Clay	Loose Sand	Medium Dense Sand
Color				
Strength Type	Mohr-Coulomb	Mohr-Coulomb	Mohr-Coulomb	Mohr-Coulomb
Unit Weight [lbs/ft ³]	130	123	115	123
Cohesion [psf]	400	200	0	0
Friction Angle [deg]	19	22	30	33



Project			AEP Rockport East Bottom Ash Pond		
Analysis Description			North-to-South Splitter Dike - Seismic		
Drawn By	Scale	1:301	Company		
Date			File Name	NS Dike - Seismic.slim	




	Project		
	AEP Rockport East Bottom Ash Pond		
	Analysis Description		
	North-to-South Splitter Dike - Rapid Drawdown		
Drawn By	Scale	Company	
	1:258		
Date	File Name		
	NS Dike - RD.slim		




SLIDEINTERPRET 6.027


Project			AEP Rockport East Bottom Ash Pond		
Analysis Description			East-to-West Splitter Dike - End of Construction		
Drawn By	Scale	1:280	Company		
Date			File Name	EW Dike - EOC.slim	



	Project		
	AEP Rockport East Bottom Ash Pond		
	Analysis Description		
	East-to-West Splitter Dike - Max Pool		
Drawn By	Scale	Company	
	1:285		
Date	File Name		
	EW Dike - Max Pool.slim		




	Project		
	AEP Rockport East Bottom Ash Pond		
	Analysis Description		
	East-to-West Splitter Dike - Seismic		
Drawn By	Scale	Company	
	1:280		
Date	File Name		
	EW Dike - Seismic.slim		



	Project		
	AEP Rockport East Bottom Ash Pond		
	Analysis Description		
	East-to-West Splitter Dike - Rapid Drawdown		
Drawn By	Scale	Company	
	1:283		
Date	File Name		
	EW Dike - RD.slim		

Appendix C- Historical Soil Borings & Geotechnical Data



PROJECT: Rockport Site PROJECT NO W6-1482 BORING: BH-361
 DATE: 3/17/77 DRILLER: G. Powers CREW: J. Hardman/J. Selbe SURFACE ELEV. _____

DEPTH		SOIL STRATA SOIL DESCRIPTION AND REMARKS	TIME	TYPE	NO.	DEPTH		FIRST 6"	2ND 6"	3RD 6"	REC
FROM	TO					FROM	TO				
		Topsoil									
	1.0										
1.0		Very stiff brown and gray silty clay		SS	1	5.0	6.5	5	8	11	10
		Very stiff brown and gray silty clay		SS	2	10.0	11.5	8	13	14	9
	13.0										
13.0		Firm brown silty fine sand		SS	3	15.0	16.5	5	5	6	8
	19.0										
19.0		Very loose brown silty fine sand		SS	4	20.0	21.5	1	2	2	1
		Very loose brown silty fine sand		SS	5	25.0	26.5	1	2	2	16
	30.0										
30.0		Very dense dark brown silty fine sand		SS	6	30.0	31.5	6	43	30	16
	34.0										
34.0		Firm brown medium to coarse silty sand		SS	7	35.0	36.5	9	10	13	8
	41.0										
41.0		Firm brown silty fine sand		SS	8	40.0	41.5	9	11	13	16
	44.0										
44.0		Firm brown medium and coarse sand		SS	9	45.0	46.5	8	11	19	16
	48.0										
48.0	51.5	Dense grayish brown silty fine to medium sand		SS	10	50.0	51.5	21	21	24	14
		Boring Terminated @ 51.5 3/17/77									

METHOD OF DRILLING (Check One)
 a. ~~WIGER~~ Rod SIZE A
 b. WASH XX WATER MUD XX
 DRILLING SIZE _____ BIT USED 2-7/8" Side Discharge
 BIT SIZE N/W LENGTH 5.0
 TURBED SAMPLES: NO. _____ SIZE _____
 SAMPLES: NO. _____
 WATER LOSSES, % _____ DEPTH _____
 SPECIAL TESTS (Hrs & Explain) _____

WEATHER Overcast 45 degrees
 NON-DRILLING TIME (Hrs.) _____
 BORING LAYOUT _____ MOVING _____
 HAULING WATER _____ STANDBY _____
 WATER LEVEL: @ _____ DATE _____ TIME _____
 @ _____ DATE _____ TIME _____
 CAVE-IN DEPTH: @ _____ DATE _____ TIME _____

REMARKS: (All remarks should be explained on the back of white copy)
 THIS IS A DRILLER'S LOG AND THE CLASSIFICATIONS HAVE NOT BEEN REVIEWED BY AN ENGINEER

PROJECT: Rockport Site PROJECT NO. W6-1482 BORING: BE-362
 DATE: 3/18/77 DRILLER: G. Powers CREW: J. Hardman/J. Selbe SURFACE ELEV. 392.7

DEPTH		SOIL STRATA SOIL DESCRIPTION AND REMARKS	TIME	TYPE	NO.	DEPTH		FIRST 6"	2ND 6"	3RD 6"	REC
FROM	TO					FROM	TO				
0		Topsoil									
	1.2										
1.2	7.5	Very stiff brown and gray fine sandy silty clay		SS	1	5.0	6.5	7	10	12	15
7.5	13.0	Stiff brown fine sandy silt		SS	2	10.0	11.5	4	4	6	16
13.0		Firm brown silty fine sand		SS	3	15.0	16.5	4	5	6	12
	23.5	Firm brown silty fine sand		SS	4	20.0	21.5	4	5	7	4
23.5	29.0	Loose brown silty fine to medium sand		SS	5	25.0	26.5	4	3	4	5
29.0		Firm brown silty fine to medium sand		SS	6	30.0	31.5	4	5	8	10
	37.0	Firm brown silty fine to medium sand		SS	7	35.0	36.5	7	6	10	9
37.0	44.0	Dense brown medium to coarse sand		SS	8	40.0	41.5	12	14	22	10
44.0		Firm brownish gray fine to medium silty sand		SS	9	45.0	46.5	12	12	11	10
51.5		Firm brownish gray fine to medium silty		SS	10	50.0	51.5	8	8	12	9
		Boring Terminated @ 51.5 3/18/77									

METHOD OF DRILLING (Check One)
 a. ~~XXXXX~~ Rod SIZE A
 b. WASH XX WATER MUD XX
 BORING SIZE _____ BIT USED _____
 CHANGING: SIZE N/W LENGTH 5'
 UNDISTURBED SAMPLES: NO. _____ SIZE _____
 BAG SAMPLES: NO. _____
 WATER LOSSES _____ DEPTH _____
 SPECIAL TESTS (Hrs & Explain) _____

WEATHER 45 degrees Overcast & windy
 NON-DRILLING TIME (Hrs) _____
 BORING LAYOUT _____ MOVING _____
 HAULING WATER _____ STANDBY _____
 WATER LEVEL: @ _____ DATE _____ TIME _____
 @ _____ DATE _____ TIME _____
 GIVE IN DEPTH: @ _____ DATE _____ TIME _____

REMARKS: (All remarks should be explained on the back of white copy) THIS IS A DRILLER'S LOG AND THE CLASSIFICATIONS HAVE NOT BEEN REVIEWED BY AN ENGINEER

PROJECT: Rockport Site PROJECT NO. W6-1482 BORING: BH-363
 DATE: 3/18/77 DRILLER: G. Powers CREW: J. Hardman/J. Selbe SURFACE ELEV. 392

DEPTH		SOIL STRATA SOIL DESCRIPTION AND REMARKS	TIME	TYPE	NO.	DEPTH		FIRST 6"	2ND 6"	3RD 6"	RE
FROM	TO					FROM	TO				
0	0.8	Topsoil									
0.8	8.0	Very stiff brown fine sandy silty clay		SS	1	5.0	6.5	6	9	12	14
8.0		Loose brown silty fine sand		SS	2	10.0	11.5	4	4	5	15
	20.5	Loose brown silty fine sand		SS	3	15.0	16.5	4	5	5	12
20.5	23.5	Firm brown silty fine sand		SS	4	20.0	21.5	2	5	8	10
23.5		Firm brown fine to medium sand		SS	5	25.0	26.5	5	6	6	8
		Firm brown fine to medium sand		SS	6	30.0	31.5	6	7	9	10
	38.0	Firm brown fine to medium sand		SS	7	35.0	26.5	8	8	14	7
38.0		Firm brown medium to coarse sand		SS	8	40.0	41.5	9	10	16	12
		Firm brown medium to coarse sand		SS	9	45.0	46.5	8	14	13	8
	47.0										
47.0	51.5	Firm grayish brown silty fine to medium sand		SS	10	50.0	51.5	7	10	10	12
		Boring Terminated @ 51.5 3/18/77									

METHOD OF DRILLING (Check One)
 a. ~~AUX~~ Rod SIZE A
 b. WASH XX WATER MUD XX
 BORING SIZE _____ BIT USED 2-7/8" Side Discharge
 CA 3: SIZE N/W LENGTH 5.0
 UNDISTURBED SAMPLES: NO. _____ SIZE _____
 JAG SAMPLES: NO. _____
 WATER LOSSES % _____ DEPTH _____
 SPECIAL TESTS (Hrs & Explain) _____

WEATHER 45 degrees Overcast Windy
 NON-DRILLING TIME (Hrs) _____
 BORING LAYOUT _____ MOVING _____
 HAULING WATER _____ STANDBY _____
 WATER LEVEL: @ _____ DATE _____ TIME _____
 @ _____ DATE _____ TIME _____
 CAVE-IN DEPTH: @ _____ DATE _____ TIME _____

REMARKS: (All remarks should be explained on the back of white copy) THIS IS A DRILLER'S LOG AND THE CLASSIFICATIONS HAVE

PROJECT: Rockport Site

PROJECT NO. W6-1482

BORING: BH=364

DATE: 3/15/77

DRILLER: G. Powers

CREW: J. Hardman/J. Selbe

SURFACE ELEV. 389.5

DEPTH		SOIL STRATA SOIL DESCRIPTION AND REMARKS	TIME	TYPE	NO.	DEPTH		FIRST 6"	2ND 6"	3RD 6"	REC.
FM	TO					FROM	TO				
0	1.4	Topsoil									
1.4		Stiff brown and gray silty clay traces fine sand		SS	1	5.0	6.5	4	6	7	16
	13.0	Stiff brown and gray silty clay traces fine sand		SS	2	10.0	11.5	3	4	6	12
13.0		Loose brown silty fine sand		SS	3	15.0	16.5	3	4	3	17
	24.0	Loose brown silty fine sand		SS	4	20.0	21.5	3	3	3	8
24.0		Firm brown fine to medium sand		SS	5	25.0	26.5	6	8	8	7
	34.5	Firm brown fine to medium sand		SS	6	30.0	31.5	6	8	9	8
34.5		Firm brown medium to coarse sand		SS	7	35.0	36.5	5	8	10	8
	43.0	Firm brown medium to coarse sand		SS	8	40.0	41.5	5	6	8	7
43.0		Loose brown medium to coarse sand & gravel		SS	9	45.0	46.5	4	3	3	8
	47.0										
47.0	51.5	Firm brown medium to coarse sand traces gravel		SS	10	50.0	51.5	8	9	13	8
		Boring Terminated @ 51.5 3/15/77									

METHOD OF DRILLING (Check One)

a. AUGER Rod SIZE A
 b. WASH XX WATER MUD XX

BIT USED 2-7/8" Side Discharge
 CASING: SIZE NW LENGTH 5'
 UNDISTURBED SAMPLES: NO. SIZE
 BAG SAMPLES: NO.
 WATER LOSSES: DEPTH
 SPECIAL TESTS (List & Explain)

WEATHER 70 degrees clear
 NON-DRILLING TIME (Hrs)
 BORING LAYOUT MOVING
 HAULING WATER STANDBY
 WATER LEVEL: @ DATE TIME
 @ DATE TIME
 CAVE-IN DEPTH: @ DATE TIME

REMARKS (All remarks should be explained on the back of white copy) THIS IS A DRILLER'S LOG THE CLASSIFICATION

PROJECT: Rockport Site PROJECT NO. W6-1482 BORING: BH=365
 DATE: 3/15/77 DRILLER: G. Powers CREW: J. Hardman/J. Selbe SURFACE ELEV. _____

DEPTH	SOIL STRATA	TIME	TYPE	NO.	DEPTH		FIRST 6"	2ND 6"	3RD 6"	REC.
					FROM	TO				
0	Topsoil									
1.3	Stiff brown and gray silty clay traces		SS	1	5.0	6.5	3	5	9	18
11.0	Stiff brown fine sandy silty tan clay		SS	2	10.0	11.5	4	4	8	18
13.5	Loose brown silty fine sand		SS	3	15.0	16.5	2	3	4	12
19.0	Firm brown fine sand silt traces clay		SS	4	20.0	21.5	3	2	3	14
25.5	Firm brown and gray silty fine sand		SS	5	25.0	26.5	2	5	8	12
28.0	Firm brown silty fine sand		SS	6	30.0	31.5	8	10	10	6
35.5	Firm brown silty medium to coarse sand		SS	7	35.0	36.5	6	11	10	9
40.0	Dense brown silty medium to coarse sand traces gravel		SS	8	40.0	41.5	13	25	25	10
42.0	Firm brown silty medium to coarse sand traces gravel		SS	9	45.0	46.5	10	12	12	8
47.5	Firm gray fine to medium silty sand traces gravel		SS	10	50.0	51.5	8	7	9	8
Boring Terminated @ 51.5 3/15/77										

METHOD OF DRILLING (Check One)
 a. ~~AXXR~~ Rod SIZE A
 b. WASH XX WATER XX MUD XX
 BORING SIZE _____ BIT USED 2-7/8" Side Discharge
 CASING: SIZE NW LENGTH 5.0'
 UNDISTURBED SAMPLES: NO. _____ SIZE _____
 BAG SAMPLES: NO. _____
 WATER LOSSES: % _____ DEPTH _____
 SPECIAL TESTS (Hrs. & Explain) _____

WEATHER 65 degrees clear
 NON-DRILLING TIME (Hrs.) _____
 BORING LAYOUT _____ MOVING _____
 HAULING WATER _____ STANDBY _____
 WATER LEVEL: @ _____ DATE _____ TIME _____
 @ _____ DATE _____ TIME _____
 CAVE-IN DEPTH: @ _____ DATE _____ TIME _____

REMARKS: (All remarks should be explained on the back of white copy) THIS IS A DRILLER'S LOG! THE CLASSIFICATIONS HAVE NOT BEEN REVIEWED BY AN ENGINEER

PROJECT: Rockport Site

PROJECT NO. W6-1482

BORING: BH-366

DATE: 3/15/77

DRILLER: G. Powers

CREW: J. Hardman/J. Selbe

SURFACE ELEV.

DEPTH		SOIL STRATA SOIL DESCRIPTION AND REMARKS	TIME	TYPE	NO.	DEPTH		FIRST 6"	2ND 6"	3RD 6"	RFC
FROM	TO					FROM	TO				
	1.5	Topsoil									
1.5	9.0	Very stiff brown and gray silty clay traces fine sand		SS	1	5.0	6.5	3	7	14	18
9.0	15.0	Firm brown silty fine sand traces clay		SS	2	10.0	11.5	4	5	8	16
15.0	17.0	Loose brown silty fine sand traces clay		SS	3	15.0	16.5	2	4	6	16
17.0	24.0	loose brown silty fine sand		SS	4	20.0	21.5	4	4	6	8
24.0	33.5	Firm brown fine to medium fine sand		SS	5	25.0	26.5	4	7	12	7
33.5	37.0	Firm brown fine to medium fine sand		SS	6	30.0	31.5	5	8	9	7
37.0	47.5	Firm brown fine to medium sand traces		SS	7	35.0	36.5	5	8	9	6
47.5	51.5	Firm brown medium to coarse silty sand		SS	8	40.0	41.5	8	11	12	7
		Firm brown medium to coarse silty sand		SS	9	45.0	46.5	7	12	16	11
		Firm brown medium to coarse sand some gravel		SS	10	50.0	51.5	7	7	9	8
		Boring Terminated @ 51.5 3/15/77									

TYPE OF DRILLING (Check One)
 Rod
 Rod SIZE A
 WATER
 MUD MUD
 BIT USED 2-7/8" Side Discharge
 LENGTH 5.0
 SAMPLES: NO
 SIZE
 DEPTH

WEATHER 50 degrees overcast
 NON-DRILLING TIME IN
 BORING LAYOUT
 MOVING
 HAULING WATER
 STANDBY
 WATER LEVEL: @
 DATE TIME
 @
 DATE TIME
 CAVE IN DEPTH: @
 DATE TIME

REMARKS (All remarks should be explained on the back of white copy) THIS IS A DRILLER'S LOG AND THE CLASSIFICATIONS HAVE NOT BEEN REVIEWED BY AN ENGINEER

PROJECT: Rockport Site PROJECT NO. W6-1482 BORING: Bh-367

DATE: 3/16/77 DRILLER: G. Powers CREW: J. Hardman/J. Selbe SURFACE ELEV. _____

DEPTH		SOIL STRATA SOIL DESCRIPTION AND REMARKS	TIME	TYPE	NO.	DEPTH		FIRST 5"	2ND 5"	3RD 5"	REC
FROM	TO					FROM	TO				
0		Topsoil									
	1.2										
1.2		Firm brown silty fine sand traces clay		SS	1	5.0	6.5	3	4	7	14
	8.0										
8.0		Loose brown silty fine sand		SS	2	10.0	11.5	3	3	5	12
		Loose brown silty fine sand		SS	3	15.0	16.5	3	3	4	10
		Loose brown silty fine sand		SS	4	20.0	21.5	3	5	5	8
	23.0										
23.0		Firm brown silty fine to medium sand		SS	5	25.0	26.5	7	10	14	7
		Firm brown silty fine to medium sand		SS	6	30.0	31.5	7	8	9	6
		Firm brown silty fine to medium sand		SS	7	35.0	36.5	5	7	10	6
		Firm brown silty fine to medium sand		SS	8	40.0	41.5	8	11	14	6
	44.0										
44.0		Firm brown silty medium to coarse sand		SS	9	45.0	46.5	10	15	13	8
		Firm brown silty medium to coarse sand		SS	10	50.0	51.5	7	12	11	10
	51.5										
		Boring Terminated @ 51.5									

METHOD OF DRILLING (Check One)
 a. ~~XXX~~ Rod SIZE A
 b. WASH XX WATER XX MUD XX
 DRILLING SIZE _____ BIT USED 2-7/8" Side Discharge
 CASINGS: SIZE NW LENGTH 5.0'
 UNL. TURBED SAMPLES: NO. _____ SIZE _____
 TAG SAMPLES: NO. _____
 WATER LOSSES % _____ DEPTH _____
 SPECIAL TESTS (Hrs & Explain) _____

WEATHER Clear 60 degrees
 NON-DRILLING TIME (Hrs.) _____
 BORING LAYOUT _____ MOVING _____
 HAULING WATER _____ STANDBY _____
 WATER LEVEL: @ _____ DATE _____ TIME _____
 @ _____ DATE _____ TIME _____
 CAVE-IN DEPTH: @ _____ DATE _____ TIME _____

REMARKS: (All remarks should be explained on the back of white copy) THIS IS A DRILLER'S LOG AND THE CLASSIFICATIONS HAVE NOT BEEN REVIEWED BY AN ENGINEER

PROJECT: Rockport Site

PROJECT NO. W6-1482

BORING: BH-368

DATE: 3/16/77

DRILLER: G. Powers

CREW: J. Hardman/J. Selbe

SURFACE ELEV. 392.3

DEPTH		SOIL STRATA SOIL DESCRIPTION AND REMARKS	TIME	TYPE	NO.	DEPTH		FIRST 6"	2ND 6"	3RD 6"	REC
FROM	TO					FROM	TO				
J		Topsoil									
	0.7										
0.7		Very stiff brown silty clay		SS	1	5.0	6.5	3	12	15	18
	9.0										
9.0		Firm brown silty fine sand		SS	2	10.0	11.5	7	7	8	14
		Firm brown silty fine sand		SS	3	15.0	16.5	5	5	6	9
		Firm brown silty fine sand		SS	4	20.0	21.5	5	6	8	8
	24.0										
24.0		Firm brown silty fine to medium sand		SS	5	25.0	26.5	8	10	13	6
		Firm brown silty fine to medium sand		SS	6	30.0	31.5	5	7	7	7
	33.0										
33.0		Firm brown medium to coarse sand		SS	7	35.0	36.5	6	6	8	5
	37.5										
37.5		Firm brown fine to medium silty sand		SS	8	40.0	41.5	5	7	8	6
	44.0										
44.0		Firm brown medium to coarse sand		SS	9	45.0	46.5	5	10	13	9
	51.5										
51.5		Firm brown medium to coarse sand		SS	10	50.0	51.5	10	12	12	12
		Boring Terminated @ 51.5'									

METHOD OF DRILLING (Check One)
 a. ~~XXXX~~ Rod SIZE A
 b. WASH XX WATER MUD XX
 BOREHOLE SIZE BIT USED 2-7/8" Side Discharge
 CAUTION: SIZE NW LENGTH 5.0'
 UNDISTURBED SAMPLES: NO. SIZE
 TAG SAMPLES: NO.
 WATER LOSSES, % DEPTH
 SPECIAL TESTS (Hrs. & Explain)

WEATHER Clear 45 degrees
 NON-DRILLING TIME (Hrs.)
 BORING LAYOUT MOVING
 HAULING WATER STANDBY
 WATER LEVEL: @ DATE TIME
 @ DATE TIME
 CAVE-IN DEPTH: @ DATE TIME

REMARKS: (All remarks should be explained on the back of white copy) THIS IS A DRILLER'S LOG AND THE CLASSIFICATIONS HAVE NO BEEN REVIEWED BY ALL ENGINEERS

PROJECT: Rockport Site

PROJECT NO. W6-1482

BORING: BH-369

DATE: 3/18/77 DRILLER: R. Stevens CREW: B. Blackford/D. Woodens SURFACE ELEV. 394.3

DEPTH		SOIL STRATA SOIL DESCRIPTION AND REMARKS	TIME	TYPE	NO.	DEPTH		FIRST 6"	2ND 6"	3RD 6"	REC.
FROM	TO					FROM	TO				
0	12"	Topsoil									
		Very stiff brown and tan clay		SS	1	5	6.5	8	12	15	18
	9.0										
9.0		Loose brown very silty fine sand		SS	2	10	11.5	3	3	4	12
	12.7										
12.7		Firm brown medium sand		SS	3	15	16.5	5	6	7	5
	18.0										
18.0		Loose gray and brown silty fine to medium sand		SS	4	20	21.5	3	4	5	6
	22.1										
22.1		Firm brown medium sand		SS	5	25	26.5	9	10	10	6
	28.5										
28.5		Loose brown medium sand w/traces fine gravel		SS	6	30	31.5	3	4	4	5
	32.0										
32.0		Firm brown medium to coarse sand		SS	7	35	36.5	7	10	16	8
		Firm brown medium to coarse sand		SS	8	40	41.5	10	11	13	7
	44.0										
44.0		Dense brown medium to coarse sand		SS	9	45	46.5	11	15	18	10
	47.5										
47.5		Dense brown medium to coarse sand w/fine gravel		SS	10	50	51.5	11	19	26	10
		Boring Terminated @ 51.5'									

METHOD OF DRILLING (Check One)

a AIRLIFT Rod SIZE A

b WASH XX WATER MUD XX

BORING SIZE 2-7/8" BIT USED 2-7/8" Side Discharge

CLOG: SIZE NW 5" LENGTH

UNDISTURBED SAMPLES: NO. SIZE

TAG SAMPLES: NO.

WATER LOSSES: % DEPTH

SPECIAL TESTS (Hrs. & Explain)

WEATHER Cloudy 50 degrees

NON-DRILLING TIME (Hrs.)

BORING LAYOUT MOVING



HAULING WATER STANDBY

WATER LEVEL: @ DATE TIME

@ DATE TIME

CAVE-IN DEPTH: @ DATE TIME

REMARKS: (All remarks should be explained on the back of white copy) THIS IS A DRILLER'S LOG AND THE CLASSIFICATIONS HAVE NOT BEEN REVIEWED BY AN ENGINEER



NOTE
 THE AERIAL TOPOGRAPHY WAS OBTAINED FROM HENDERSON AERIAL SURVEYS INC., DATED 11/10/2007.

STATE ROUTE 231

LEGEND
 B-1 SOIL BORING

REV	DATE	BY	DESCRIPTION

Terracon
 Consulting Engineers and Scientists
 800 MORRISON ROAD
 COLUMBUS, OHIO 43220
 PH. (614) 863-3113 FAX. (614) 863-0475

SITE PLAN
 ROCKPORT PLANT
 AMERICAN ELECTRIC POWER
 ROCKPORT PLANT BOTTOM ASH POND COMPLEX
 ROCKPORT

EXHIBIT A-3

DESIGNED BY:	BMY
DRAWN BY:	DAB
APPROV. BY:	MSF
SCALE:	1"=300'
DATE:	10/15/15
JOB NO.:	N4155126
ACAD NO.:	PSET2
SHEET NO.:	1 OF 1

BORING LOG NO. B-1

PROJECT: Rockport Plant Impoundment Certification

CLIENT: American Electric Power
Columbus, Ohio

SITE:

Rockport, Indiana

GRAPHIC LOG	LOCATION See Exhibit A-3	DEPTH	ELEVATION (Ft.)	DEPTH (Ft.)	WATER LEVEL OBSERVATIONS	SAMPLE TYPE	RECOVERY (in.)	FIELD TEST RESULTS	LABORATORY TORVANE/HP (tsf)	ATTERBERG LIMITS
	Latitude: 37.918487° Longitude: -87.039045°									LL-PL-PI
		0.3	389.5							
	TOPSOIL (3")									
	SANDY FAT CLAY (CH) , trace gravel, brown, stiff						14	5-3-4-4 N=7	3.0 (HP)	
							12	5-4-4-5 N=8	1.0 (HP)	69-26-43
		6.0	383.5	5			18			
	LEAN CLAY (CL) , trace sand, gray and brown, stiff						24	2-3-4-5 N=7	2.0 (HP)	
							24			42-22-20
				10			24	2-3-5-6 N=8	1.25 (HP)	
							24	2-4-5-6 N=9	2.0 (HP)	
				15			24			28-18-10
		17.5	372		▽		24	2-3-3-3 N=6	1.25 (HP)	
	SANDY SILT (ML) , brown, loose	18.5	371				18	2-4-4-4 N=8		
	POORLY GRADED SAND (SP) , brown, loose			20						
							24	3-7-8-9 N=15		
	POORLY GRADED SAND (SP) , trace gravel, brown, medium dense	23.0	366.5	25						

Stratification lines are approximate. In-situ, the transition may be gradual.

Hammer Type: Automatic

Advancement Method:
3.25" Hollow Stem Auger

See Exhibit A-1 for description of field procedures

Notes:

Abandonment Method:
Boring backfilled with cement/bentonite grout upon completion.

See Appendix B for description of laboratory procedures and additional data (if any).
See Appendix C for explanation of symbols and abbreviations.

WATER LEVEL OBSERVATIONS

▽ Water encountered at 17.5 feet while sampling



Boring Started: 9/3/2015

Boring Completed: 9/4/2015

Drill Rig: Track

Driller: Davis

Project No.: N4155126

Exhibit: A-4

THIS BORING LOG IS NOT VALID IF SEPARATED FROM ORIGINAL REPORT. GEO SMART LOG-NO WELL ROCKPORT CCR BORINGS.GPJ TERRACON2015.GDT 10/16/15

BORING LOG NO. B-1

PROJECT: Rockport Plant Impoundment Certification

CLIENT: American Electric Power
Columbus, Ohio

SITE:

Rockport, Indiana

GRAPHIC LOG	LOCATION See Exhibit A-3 Latitude: 37.918487° Longitude: -87.039045°	DEPTH (Ft.)	WATER LEVEL OBSERVATIONS	SAMPLE TYPE	RECOVERY (in.)	FIELD TEST RESULTS	LABORATORY TORVANE/HP (tsf)	ATTERBERG LIMITS
	Surface Elev.: 389.7 (Ft.) ELEVATION (Ft.)							LL-PL-PI
	POORLY GRADED SAND (SP) , trace gravel, brown, medium dense <i>(continued)</i>	30		X	24	4-5-5-5 N=10		
	POORLY GRADED SAND (SP) , trace gravel, brown, medium dense	33.0 35.0		X	24	4-6-7-7 N=13		
	Boring Terminated at 35 Feet	35						

Stratification lines are approximate. In-situ, the transition may be gradual.

Hammer Type: Automatic

Advancement Method:
3.25" Hollow Stem Auger

See Exhibit A-1 for description of field procedures

Notes:

Abandonment Method:
Boring backfilled with cement/bentonite grout upon completion.

See Appendix B for description of laboratory procedures and additional data (if any).

See Appendix C for explanation of symbols and abbreviations.

WATER LEVEL OBSERVATIONS

∇ Water encountered at 17.5 feet while sampling



Boring Started: 9/3/2015

Boring Completed: 9/4/2015

Drill Rig: Track

Driller: Davis

Project No.: N4155126

Exhibit: A-4

THIS BORING LOG IS NOT VALID IF SEPARATED FROM ORIGINAL REPORT. GEO SMART LOG-NO WELL ROCKPORT CCR BORINGS.GPJ TERRACON2015.GDT 10/16/15

BORING LOG NO. B-2

PROJECT: Rockport Plant Impoundment Certification

CLIENT: American Electric Power
Columbus, Ohio

SITE:

Rockport, Indiana

THIS BORING LOG IS NOT VALID IF SEPARATED FROM ORIGINAL REPORT. GEO SMART LOG-NO WELL. ROCKPORT CCR BORINGS.GPJ TERRACON2015.GDT 10/16/15

GRAPHIC LOG	LOCATION See Exhibit A-3 Latitude: 37.918457° Longitude: -87.038804°	DEPTH (Ft.)	WATER LEVEL OBSERVATIONS	SAMPLE TYPE	RECOVERY (in.)	FIELD TEST RESULTS	LABORATORY TORVANE/HP (tsf)	ATTERBERG LIMITS
	Surface Elev.: 397.4 (Ft.) ELEVATION (Ft.)							LL-PL-PI
0.1	TOPSOIL (1")	397.9						
	FILL - LEAN CLAY (CL) , trace sand, brown				19	6-10-14-16 N=24		28-15-13
4.0		393.5			4	15-12-10-10 N=22		
	FILL - SANDY SILT (ML) , brown				24			19-16-3
6.0		391.5			23	2-3-5-6 N=8		
	FILL - SANDY LEAN CLAY (CL) , trace gravel, gray and brown 5" poorly graded sand seam from 6-6.4'				24	3-7-10-17 N=17	3.25 (HP)	
8.0		389.5			24			30-21-9
	LEAN CLAY (CL) , trace sand, gray, very stiff				24	3-4-6-8 N=10	1.5 (HP)	
12.0		385.5			24	3-5-7-9 N=12	1.75 (HP)	
	LEAN CLAY (CL) , brown, stiff				17	6-10-12-14 N=22	2.75 (HP)	35-15-20
14.0		383.5			24			
	SANDY LEAN CLAY (CL) , trace gravel, gray and orange, stiff				24	3-4-4-5 N=8		
20.8		376.5			23	3-3-4-5 N=7		
	CLAYEY SAND (SC) , brown, loose				21	2-3-4-4		
22.7		374.5						
	POORLY GRADED SAND WITH SILT (SP-SM) , trace gravel, brown, loose							

Stratification lines are approximate. In-situ, the transition may be gradual.

Hammer Type: Automatic

Advancement Method:
3.25" Hollow Stem Auger

See Exhibit A-1 for description of field procedures

Notes:

A monitoring well was installed in an offset hole approximately 10 feet south of the boring.

Abandonment Method:
Boring backfilled with cement/bentonite grout upon completion.

See Appendix B for description of laboratory procedures and additional data (if any).
See Appendix C for explanation of symbols and abbreviations.

WATER LEVEL OBSERVATIONS

Water encountered at 25.1 feet while sampling



Boring Started: 9/4/2015

Boring Completed: 9/4/2015

Drill Rig: Track

Driller: Davis

Project No.: N4155126

Exhibit: A-5

BORING LOG NO. B-2

PROJECT: Rockport Plant Impoundment Certification

CLIENT: American Electric Power
Columbus, Ohio

SITE:

Rockport, Indiana

GRAPHIC LOG	LOCATION See Exhibit A-3	DEPTH	ELEVATION (Ft.)	DEPTH (Ft.)	WATER LEVEL OBSERVATIONS	SAMPLE TYPE	RECOVERY (in.)	FIELD TEST RESULTS	LABORATORY TORVANE/HP (tsf)	ATTERBERG LIMITS
	Latitude: 37.918457° Longitude: -87.038804°									LL-PL-PI
	Surface Elev.: 397.4 (Ft.)	25.5	372					N=7		
	POORLY GRADED SAND WITH SILT (SP-SM) , trace gravel, brown, loose to medium dense						21			
							24	6-6-5-4 N=11		
							18	2-2-5-3 N=7		
				30			24	2-3-4-4 N=7		
		32.5	365				19	1-2-2-2 N=4		
	SILTY SAND (SM) , brown, loose									
	3" clay seam at 33.7'	34.0	363.5							
	SILTY SAND (SM) , trace gravel, brown, loose						8	2-3-3-4 N=6		
				35			17	2-2-2-4 N=4		
		38.0	359.5				1	3-4-5-5 N=9		
	POORLY GRADED SAND (SP) , trace gravel, brown, loose to medium dense									
				40			9	3-5-6-5 N=11		
		42.0	355.5				6	4-6-9-12 N=15		
	POORLY GRADED SAND (SP) , trace gravel, brown, medium dense									
		44.0	353.5							
	Boring Terminated at 44 Feet									

Stratification lines are approximate. In-situ, the transition may be gradual.

Hammer Type: Automatic

Advancement Method:
3.25" Hollow Stem Auger

See Exhibit A-1 for description of field procedures

Notes:

Abandonment Method:
Boring backfilled with cement/bentonite grout upon completion.

See Appendix B for description of laboratory procedures and additional data (if any).

See Appendix C for explanation of symbols and abbreviations.

WATER LEVEL OBSERVATIONS

Water encountered at 25.1 feet while sampling



Boring Started: 9/4/2015

Boring Completed: 9/4/2015

Drill Rig: Track


Driller: Davis

Project No.: N4155126

Exhibit: A-5

THIS BORING LOG IS NOT VALID IF SEPARATED FROM ORIGINAL REPORT. GEO SMART LOG-NO WELL ROCKPORT CCR BORINGS.GPJ TERRACON2015.GDT 10/16/15

Particle Size Distribution Report



% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	4.2	31.0	0.7	1.7	14.7	47.7

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	PASS? (X=NO)
3/8	100.0		
#4	95.8		
#10	64.8		
#20	64.7		
#40	64.1		
#100	63.1		
#200	62.4		
0.0240 mm.	57.5		
0.0155 mm.	56.0		
0.0092 mm.	53.3		
0.0067 mm.	50.1		
0.0049 mm.	47.5		
0.0029 mm.	43.8		

Soil Description

Brown SANDY FAT CLAY, trace gravel

Atterberg Limits

PL= 26 LL= 69 PI= 43

Coefficients

D₉₀= 3.9559 D₈₅= 3.4817 D₆₀= 0.0406
D₅₀= 0.0066 D₃₀= D₁₅=
D₁₀= C_u= C_c=

Classification

USCS= CH AASHTO= A-7-6(25)

Remarks

F.M.=1.79

* (no specification provided)


Source of Sample: B-1 Depth: 2.0'-4.0'
Sample Number: S-2

Date: 9-21-15

TERRACON CONSULTANTS, INC. Columbus, Ohio	Client: American Electric Power Project: Rockport Plant Impoundment Certification Project No: N4155126 Exhibit B-2
--	--

Tested By: DS Checked By: AM

LIQUID AND PLASTIC LIMITS TEST REPORT




MATERIAL DESCRIPTION	LL	PL	PI	%<#40	%<#200	USCS
● Brown SANDY FAT CLAY, trace gravel	69	26	43	64.1	62.4	CH

Project No. N4155126 Client: American Electric Power Project: Rockport Plant Impoundment Certification Source of Sample: B-1 Depth: 2.0'-4.0' Sample Number: S-2	Remarks: ● Date: 9-21-15
TERRACON CONSULTANTS, INC. Columbus, Ohio	
Exhibit B-3	

Tested By: DS Checked By: AM

Particle Size Distribution Report



% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	0.0	0.3	12.3	83.1	1.4	2.9

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	PASS? (X=NO)
#4	100.0		
#10	99.7		
#20	98.6		
#40	87.4		
#100	7.7		
#200	4.3		
0.0357 mm.	4.3		
0.0227 mm.	3.3		
0.0131 mm.	3.3		
0.0093 mm.	3.3		
0.0066 mm.	3.3		
0.0038 mm.	2.3		

Soil Description

Brown poorly graded SAND

Atterberg Limits

PL= NP LL= NP PI= NP

Coefficients

D₉₀= 0.4785 D₈₅= 0.4068 D₆₀= 0.2938
D₅₀= 0.2631 D₃₀= 0.2102 D₁₅= 0.1721
D₁₀= 0.1577 C_u= 1.86 C_c= 0.95

Classification

USCS= SP AASHTO= A-3

Remarks

F.M.=1.37


* (no specification provided)

Source of Sample: B-1 Depth: 18.0'-20.0' Date: 9-21-15
Sample Number: S-7

TERRACON CONSULTANTS, INC. Columbus, Ohio	Client: American Electric Power Project: Rockport Plant Impoundment Certification Project No: N4155126 Exhibit B-4
--	--

Tested By: DS Checked By: AM

Particle Size Distribution Report



% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	0.2	1.6	63.7	32.8	0.4	1.3

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	PASS? (X=NO)
3/8	100.0		
#4	99.8		
#10	98.2		
#20	90.4		
#40	34.5		
#100	2.4		
#200	1.7		
0.0362 mm.	1.8		
0.0229 mm.	1.3		
0.0132 mm.	1.3		
0.0094 mm.	1.3		
0.0066 mm.	1.3		
0.0038 mm.	1.3		

Soil Description

Brown poorly graded SAND, trace gravel

Atterberg Limits

PL= NP LL= NP PI= NP

Coefficients

D₉₀= 0.8432 D₈₅= 0.7776 D₆₀= 0.5735
D₅₀= 0.5129 D₃₀= 0.3986 D₁₅= 0.2992
D₁₀= 0.2576 C_u= 2.23 C_c= 1.08

Classification

USCS= SP AASHTO= A-1-b

Remarks

F.M.=2.26


* (no specification provided)

Source of Sample: B-1 Depth: 28.0'-30.0' Date: 9-21-15
Sample Number: S-9

TERRACON CONSULTANTS, INC. Columbus, Ohio	Client: American Electric Power Project: Rockport Plant Impoundment Certification Project No: N4155126 Exhibit B-5
--	--

Tested By: DS Checked By: AM

Particle Size Distribution Report



% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	2.9	21.1	60.5	12.9	2.6	

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	PASS? (X=NO)
3/8	100.0		
#4	97.1		
#10	76.0		
#20	34.3		
#40	15.5		
#100	3.8		
#200	2.6		

Soil Description

Brown poorly graded SAND, trace gravel

Atterberg Limits

PL= NP LL= NP PI= NP

Coefficients

D₉₀= 3.0772 D₈₅= 2.5603 D₆₀= 1.4351
D₅₀= 1.1849 D₃₀= 0.7595 D₁₅= 0.4140
D₁₀= 0.2999 C_u= 4.79 C_c= 1.34

Classification

USCS= SP AASHTO= A-1-b

Remarks

F.M.=3.34


* (no specification provided)

Source of Sample: B-1 Depth: 33.0'-35.0' Date: 9-21-15
Sample Number: S-10

TERRACON CONSULTANTS, INC. Columbus, Ohio	Client: American Electric Power Project: Rockport Plant Impoundment Certification Project No: N4155126 Exhibit B-6
--	--

Tested By: DS Checked By: AM

Particle Size Distribution Report



% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	0.4	14.9	0.7	14.9	39.8	29.3

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	PASS? (X=NO)
3/8	100.0		
#4	99.6		
#10	84.7		
#20	84.5		
#40	84.0		
#100	76.6		
#200	69.1		
0.0279 mm.	55.0		
0.0185 mm.	47.4		
0.0111 mm.	40.5		
0.0081 mm.	35.0		
0.0058 mm.	30.9		
0.0034 mm.	26.1		

Soil Description

FILL: Brown sandy lean clay, trace gravel

Atterberg Limits
 PL= 15 LL= 28 PI= 13

Coefficients
 D₉₀= 2.7745 D₈₅= 2.0607 D₆₀= 0.0375
 D₅₀= 0.0215 D₃₀= 0.0054 D₁₅=
 D₁₀= C_u= C_c=

Classification
 USCS= CL AASHTO= A-6(6)

Remarks
 F.M.=0.86



* (no specification provided)

Source of Sample: B-2 Depth: 0.0'-2.0' Date: 9-21-15
 Sample Number: S-1

TERRACON CONSULTANTS, INC. Columbus, Ohio	Client: American Electric Power Project: Rockport Plant Impoundment Certification Project No: N4155126	Exhibit B-7
--	---	--------------------

Tested By: DS Checked By: AM

LIQUID AND PLASTIC LIMITS TEST REPORT



MATERIAL DESCRIPTION	LL	PL	PI	%<#40	%<#200	USCS
● FILL: Brown sandy lean clay, trace gravel	28	15	13	84.0	69.1	CL

Project No. N4155126 **Client:** American Electric Power
Project: Rockport Plant Impoundment Certification

Source of Sample: B-2 **Depth:** 0.0'-2.0'
Sample Number: S-1

Remarks:
● Date: 9-21-15


TERRACON CONSULTANTS, INC.

Columbus, Ohio

Exhibit B-8

Tested By: DS **Checked By:** AM

Particle Size Distribution Report



% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	14.2	0.5	6.1	2.0	13.7	33.3	30.2

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	PASS? (X=NO)
1.5	100.0		
1.0	85.8		
3/4	85.8		
1/2	85.8		
3/8	85.8		
#4	85.3		
#10	79.2		
#20	78.4		
#40	77.2		
#100	69.6		
#200	63.5		
0.0275 mm.	52.9		
0.0181 mm.	47.2		
0.0109 mm.	40.8		
0.0079 mm.	36.3		
0.0057 mm.	31.8		
0.0034 mm.	26.7		

Soil Description

Gray and orange SANDY LEAN CLAY, trace gravel

Atterberg Limits

PL= 15 LL= 35 PI= 20

Coefficients

D₉₀= 30.0206 D₈₅= 4.4748 D₆₀= 0.0517
D₅₀= 0.0223 D₃₀= 0.0049 D₁₅=
D₁₀= C_u= C_c=

Classification

USCS= CL AASHTO= A-6(10)

Remarks

F.M.=1.61


* (no specification provided)

Source of Sample: B-2 Depth: 16.0'-18.0' Date: 9-21-15
Sample Number: S-7

TERRACON CONSULTANTS, INC. Columbus, Ohio	Client: American Electric Power Project: Rockport Plant Impoundment Certification Project No: N4155126 Exhibit B-9
--	--

Tested By: DS Checked By: AM

LIQUID AND PLASTIC LIMITS TEST REPORT



MATERIAL DESCRIPTION	LL	PL	PI	%<#40	%<#200	USCS
● Gray and orange SANDY LEAN CLAY, trace gravel	35	15	20	77.2	63.5	CL

Project No. N4155126 **Client:** American Electric Power
Project: Rockport Plant Impoundment Certification
Source of Sample: B-2 **Depth:** 16.0'-18.0'
Sample Number: S-7

Remarks:
 ● Date: 9-21-15


TERRACON CONSULTANTS, INC.

Columbus, Ohio

Exhibit B-10

Tested By: DS **Checked By:** AM

Particle Size Distribution Report



% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	0.2	1.0	15.0	78.3	0.8	4.7

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	PASS? (X=NO)
3/8	100.0		
#4	99.8		
#10	98.8		
#20	96.2		
#40	83.8		
#100	8.2		
#200	5.5		
0.0355 mm.	5.0		
0.0224 mm.	5.0		
0.0130 mm.	5.0		
0.0092 mm.	5.0		
0.0065 mm.	5.0		
0.0038 mm.	4.1		

Soil Description

Brown poorly graded SAND with silt, trace gravel

Atterberg Limits
 PL= NP LL= NP PI= NP

Coefficients
 D₉₀= 0.4948 D₈₅= 0.4358 D₆₀= 0.3031
 D₅₀= 0.2696 D₃₀= 0.2128 D₁₅= 0.1722
 D₁₀= 0.1566 C_u= 1.94 C_c= 0.95

Classification
 USCS= SP-SM AASHTO= A-3

Remarks

F.M.=1.42

* (no specification provided)

Source of Sample: B-2 Depth: 22.0'-24.0' Date: 9-21-15
 Sample Number: S-9

TERRACON CONSULTANTS, INC. Columbus, Ohio	Client: American Electric Power Project: Rockport Plant Impoundment Certification Project No: N4155126 Exhibit B-11
--	--

Tested By: DS Checked By: AM

Particle Size Distribution Report



% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	1.2	9.5	47.4	36.0	5.9	

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	PASS? (X=NO)
3/8	100.0		
#4	98.8		
#10	89.3		
#20	75.1		
#40	41.9		
#100	8.4		
#200	5.9		

Soil Description

Brown poorly graded SAND with silt, trace gravel

Atterberg Limits

PL= NP LL= NP PI= NP

Coefficients

D₉₀= 2.1334 D₈₅= 1.3167 D₆₀= 0.6037
 D₅₀= 0.4980 D₃₀= 0.3271 D₁₅= 0.2100
 D₁₀= 0.1667 C_u= 3.62 C_c= 1.06

Classification

USCS= SP-SM AASHTO= A-1-b

Remarks

F.M.=2.32

* (no specification provided)

Source of Sample: B-2 Depth: 28.0'-30.0' Date: 9-21-15
 Sample Number: S-12

TERRACON CONSULTANTS, INC. Columbus, Ohio	Client: American Electric Power Project: Rockport Plant Impoundment Certification Project No: N4155126 Exhibit B-12
--	--

Tested By: DS Checked By: AM

Particle Size Distribution Report



% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	0.0	0.0	0.2	56.2	43.6	

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	PASS? (X=NO)
#10	100.0		
#20	100.0		
#40	99.8		
#100	88.7		
#200	43.6		

Soil Description

Brown SILTY SAND

Atterberg Limits

PL= NP LL= NP PI= NP

Coefficients

D₉₀= 0.1621 D₈₅= 0.1384 D₆₀= 0.0932
 D₅₀= 0.0815 D₃₀= D₁₅=
 D₁₀= C_u= C_c=

Classification

USCS= SM AASHTO= A-4(0)

Remarks

F.M.=0.14


* (no specification provided)

Source of Sample: B-2 Depth: 32.0'-33.7' Date: 9-21-15
 Sample Number: S-14A

TERRACON CONSULTANTS, INC. Columbus, Ohio	Client: American Electric Power Project: Rockport Plant Impoundment Certification Project No: N4155126 Exhibit B-13
--	--

Tested By: DS Checked By: AM

Particle Size Distribution Report



% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	1.0	3.4	17.4	47.2	13.5	17.5

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	PASS? (X=NO)
3/8	100.0		
#4	99.0		
#10	95.6		
#20	89.7		
#40	78.2		
#100	50.7		
#200	31.0		
0.0328 mm.	28.0		
0.0210 mm.	25.7		
0.0121 mm.	25.0		
0.0087 mm.	21.9		
0.0062 mm.	18.9		
0.0036 mm.	15.8		

Soil Description

Brown SILTY SAND, trace gravel

Atterberg Limits

PL= NP LL= NP PI= NP

Coefficients

D₉₀= 0.8715 D₈₅= 0.6088 D₆₀= 0.2033
D₅₀= 0.1468 D₃₀= 0.0537 D₁₅=
D₁₀= C_u= C_c=

Classification

USCS= SM AASHTO= A-2-4(0)

Remarks

F.M.=1.06


* (no specification provided)

Source of Sample: B-2 Depth: 34.0'-36.0' Date: 9-21-15
Sample Number: S-15

TERRACON CONSULTANTS, INC. Columbus, Ohio	Client: American Electric Power Project: Rockport Plant Impoundment Certification Project No: N4155126 Exhibit B-14
--	---

Tested By: DS Checked By: AM

Particle Size Distribution Report



% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	11.0	12.9	45.3	28.3	2.5	

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	PASS? (X=NO)
3/4	100.0		
1/2	97.9		
3/8	97.5		
#4	89.0		
#10	76.1		
#20	60.7		
#40	30.8		
#100	4.1		
#200	2.5		

Soil Description

Brown poorly graded SAND, trace gravel

Atterberg Limits

PL= NP LL= NP PI= NP

Coefficients

D₉₀= 5.0561 D₈₅= 3.7126 D₆₀= 0.8336
D₅₀= 0.6494 D₃₀= 0.4167 D₁₅= 0.2704
D₁₀= 0.2206 C_u= 3.78 C_c= 0.94

Classification

USCS= SP AASHTO= A-1-b

Remarks

F.M.=2.98


* (no specification provided)

Source of Sample: B-2 Depth: 42.0'-44.0' Date: 9-21-15
Sample Number: S-19

TERRACON CONSULTANTS, INC. Columbus, Ohio	Client: American Electric Power Project: Rockport Plant Impoundment Certification Project No: N4155126 Exhibit B-15
--	---

Tested By: DS Checked By: AM

Particle Size Distribution Report



% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	0.1	0.2	1.5	7.2	55.1	35.9

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	PASS? (X=NO)
.375	100.0		
#4	99.9		
#10	99.7		
#20	99.2		
#40	98.2		
#60	96.4		
#140	92.6		
#200	91.0		

Material Description
BROWN GRAY LEAN CLAY

Atterberg Limits
 PL= 22 LL= 42 PI= 20

Coefficients
 D₉₀= 0.0705 D₈₅= 0.0568 D₆₀= 0.0115
 D₅₀= 0.0062 D₃₀= D₁₅=
 D₁₀= C_u= C_c=

Classification
 USCS= CL AASHTO= A-7-6(19)

Remarks

* (no specification provided)


Source of Sample: B-1 Depth: 8-10'
 Sample Number: ST-2

Date: 9-28-15

<h2 style="margin: 0;">Terracon, Inc.</h2> <p style="margin: 0;">Cincinnati, Ohio</p>	Client: AEP Project: ROCKPORT PLANT IMPROVEMENT CERTIFICATION Project No: N4155126 Exhibit 7353
---	--

Tested By: DR Checked By: GS

LIQUID AND PLASTIC LIMITS TEST REPORT



MATERIAL DESCRIPTION	LL	PL	PI	%<#40	%<#200	USCS
• BROWN GRAY LEAN CLAY	42	22	20	98.2	91.0	CL

Project No. N4155126 **Client:** AEP
Project: ROCKPORT PLANT IMPROVEMENT CERTIFICATION

• Source of Sample: B-1 **Depth:** 8-10' **Sample Number:** ST-2



Terracon, Inc.

Cincinnati, Ohio

Remarks:

Exhibit 7353

Tested By: MD **Checked By:** GS



Sample No.	1	2	3	
Initial	Water Content, %	25.2	28.6	27.0
	Dry Density, pcf	99.0	94.6	97.1
	Saturation, %	96.6	98.7	98.9
	Void Ratio	0.7033	0.7825	0.7364
	Diameter, in.	2.867	2.885	2.862
	Height, in.	5.748	5.717	5.757
At Test	Water Content, %	25.2	27.8	24.9
	Dry Density, pcf	100.4	96.3	100.7
	Saturation, %	100.0	100.0	100.0
	Void Ratio	0.6794	0.7499	0.6736
	Diameter, in.	2.854	2.867	2.827
	Height, in.	5.721	5.682	5.687
Strain rate, in./min.	0.000	0.000	0.000	
Back Pressure, tsf	3.600	3.600	3.600	
Cell Pressure, tsf	3.852	4.097	5.602	
Fail. Stress, tsf	Total Pore Pr., tsf	0.388	1.252	2.652
	Ult. Stress, tsf	3.686	3.802	4.615
$\bar{\sigma}_1$ Failure, tsf	Total Pore Pr., tsf	0.554	1.547	3.638
	$\bar{\sigma}_3$ Failure, tsf	0.166	0.295	0.986

Type of Test:

CU with Pore Pressures

Sample Type: ST

Description: BROWN GRAY LEAN CLAY

LL= 42 PL= 22 PI= 20

Assumed Specific Gravity= 2.70

Remarks:

Exhibit 7353

Client: AEP

Project: ROCKPORT PLANT IMPROVEMENT CERTIFICATION

Source of Sample: B-1 **Depth:** 8-10'

Sample Number: ST-2

Proj. No.: N4155126

Date Sampled: 9-28-15






TRIAXIAL SHEAR TEST REPORT

Terracon, Inc.
Cincinnati, Ohio

Tested By: FCE

Checked By: GS

Exhibit B-18



Client: AEP

Project: ROCKPORT PLANT IMPROVEMENT CERTIFICATION

Source of Sample: B-1

Depth: 8-10'

Sample Number: ST-2

Project No.: N4155126


Exhibit _____

Terracon, Inc.

Tested By: FCE

Checked By: GS

Particle Size Distribution Report



% +3"	% Gravel	% Sand	% Silt	% Clay
0.0	0.0	9.7	58.1	32.2

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	PASS? (X=NO)
#4	100.0		
#10	99.9		
#20	99.5		
#40	98.9		
#60	98.1		
#140	94.3		
#200	90.3		

Material Description

BROWN GRAY LEAN CLAY

Atterberg Limits

PL= 18 LL= 28 PI= 10

Coefficients

D₉₀= 0.0742 D₈₅= 0.0645 D₆₀= 0.0227
D₅₀= 0.0152 D₃₀= 0.0038 D₁₅=
D₁₀= C_u= C_c=

Classification

USCS= CL AASHTO= A-4(8)

Remarks

* (no specification provided)


Source of Sample: B-1 Depth: 14-16'
Sample Number: ST-3

Date: 10-05-15

<p style="font-size: 1.2em; font-weight: bold;">Terracon, Inc.</p> <p>Cincinnati, Ohio</p>	<p>Client: AEP Project: ROCKPORT PLANT IMPROVEMENT CERTIFICATION Project No: N4155126</p>
<p>Exhibit</p>	

Tested By: JB Checked By: GS

LIQUID AND PLASTIC LIMITS TEST REPORT



MATERIAL DESCRIPTION	LL	PL	PI	%<#40	%<#200	USCS
● BROWN GRAY LEAN CLAY	28	18	10	98.9	90.3	CL



Project No. N4155126 **Client:** AEP
Project: ROCKPORT PLANT IMPROVEMENT CERTIFICATION

● Source of Sample: B-1 **Depth:** 14-16' **Sample Number:** ST-3

Remarks:
 ● MC - 22.5%

Terracon, Inc.

Cincinnati, Ohio



Sample No.		1
Initial	Water Content, %	22.5
	Dry Density, pcf	104.7
	Saturation, %	99.5
	Void Ratio	0.6095
	Diameter, in.	2.860
At Test	Height, in.	5.734
	Water Content, %	22.9
	Dry Density, pcf	104.7
	Saturation, %	101.4
	Void Ratio	0.6095
	Diameter, in.	2.860
	Height, in.	5.734
	Strain rate, in./min.	0.057
	Back Pressure, tsf	0.000
	Cell Pressure, tsf	0.144
Fail. Stress, tsf	2.528	
Ult. Stress, tsf		
σ_1 Failure, tsf	2.672	
σ_3 Failure, tsf	0.144	

Type of Test:
Unconsolidated Undrained

Sample Type: ST

Description: BROWN GRAY LEAN CLAY

LL= 28 PL= 18 PI= 10

Assumed Specific Gravity= 2.70

Remarks:

Client: AEP

Project: ROCKPORT PLANT IMPROVEMENT CERTIFICATION

Source of Sample: B-1 **Depth:** 14-16'

Sample Number: ST-3






Proj. No.: N4155126 **Date Sampled:** 10-05-15

TRIAXIAL SHEAR TEST REPORT

Terracon, Inc.
Cincinnati, Ohio

Exhibit 7354

Tested By: FCE Checked By: GS



Stress Paths: o indicates peak + indicates end

Client: AEP

Project: ROCKPORT PLANT IMPROVEMENT CERTIFICATION

Source of Sample: B-1

Depth: 14-16'

Sample Number: ST-3

Project No.: N4155126


Exhibit _____

Terracon, Inc.

Tested By: FCE

Checked By: GS

LIQUID AND PLASTIC LIMITS TEST REPORT



MATERIAL DESCRIPTION	LL	PL	PI	%<#40	%<#200	USCS
• BROWN SANDY SILT	19	16	3	97.8	57.3	ML



Project No. N4155126 **Client:** AEP
Project: ROCKPORT PLANT IMPROVEMENT CERTIFICATION
 • **Source of Sample:** B-2 **Depth:** 4-6' **Sample Number:** ST-1

Terracon, Inc.
 Cincinnati, Ohio

Remarks:

Exhibit

Tested By: VD Checked By: GS



Sample No.		1	2
Initial	Water Content, %	15.6	17.3
	Dry Density, pcf	110.4	114.3
	Saturation, %	80.0	98.5
	Void Ratio	0.5262	0.4741
	Diameter, in.	2.853	2.844
	Height, in.	5.704	5.702
At Test	Water Content, %	18.1	15.8
	Dry Density, pcf	113.2	118.0
	Saturation, %	100.0	100.0
	Void Ratio	0.4887	0.4279
	Diameter, in.	2.829	2.814
	Height, in.	5.657	5.642
Strain rate, in./min.	0.001	0.001	
Back Pressure, tsf	3.600	3.600	
Cell Pressure, tsf	3.852	7.596	
Fail. Stress, tsf	0.883	4.618	
Total Pore Pr., tsf	3.607	5.378	
Ult. Stress, tsf			
Total Pore Pr., tsf			
$\bar{\sigma}_1$ Failure, tsf	1.127	6.836	
$\bar{\sigma}_3$ Failure, tsf	0.245	2.218	

Type of Test:

CU with Pore Pressures

Sample Type: ST

Description: BROWN SANDY SILT

LL= 19 PL= 16 PI= 3

Assumed Specific Gravity= 2.70

Remarks:

Exhibit 7355

Client: AEP

Project: ROCKPORT PLANT IMPROVEMENT CERTIFICATION






Source of Sample: B-2 **Depth:** 4-6'

Sample Number: ST-1

Proj. No.: N4155126 **Date Sampled:** 10-5-15

TRIAXIAL SHEAR TEST REPORT

Terracon, Inc.
Cincinnati, Ohio



Client: AEP

Project: ROCKPORT PLANT IMPROVEMENT CERTIFICATION

Source of Sample: B-2

Depth: 4-6'

Sample Number: ST-1

Project No.: N4155126


Exhibit _____

Terracon, Inc.

Tested By: FCE

Checked By: GS

LIQUID AND PLASTIC LIMITS TEST REPORT



MATERIAL DESCRIPTION	LL	PL	PI	%<#40	%<#200	USCS
● GRAY LEAN CLAY	30	21	9	98.1	93.0	CL

Project No. N4155126 **Client:** AEP
Project: ROCKPORT PLANT IMPROVEMENT CERTIFICATION



● Source of Sample: B-2 **Depth:** 10-12' **Sample Number:** ST-2

Remarks:
 ● Initial MC - 27.2%

Terracon, Inc.

Cincinnati, Ohio

Exhibit
 Exhibit B-29



Sample No.		1
Initial	Water Content, %	27.2
	Dry Density, pcf	94.9
	Saturation, %	94.7
	Void Ratio	0.7768
	Diameter, in.	2.860
	Height, in.	6.020
At Test	Water Content, %	27.2
	Dry Density, pcf	94.9
	Saturation, %	94.7
	Void Ratio	0.7768
	Diameter, in.	2.860
	Height, in.	6.020
Strain rate, in./min.	0.060	
Back Pressure, psi	0.000	
Cell Pressure, psi	0.750	
Fail. Stress, psi	7.691	
Ult. Stress, psi		
σ_1 Failure, psi	8.441	
σ_3 Failure, psi	0.750	

Type of Test:
Unconsolidated Undrained

Sample Type: ST

Description: GRAY LEAN CLAY

LL= 30 PL= 21 PI= 9

Assumed Specific Gravity= 2.70

Remarks:

Client: AEP

Project: ROCKPORT PLANT IMPROVEMENT CERTIFICATION

Source of Sample: B-2 **Depth:** 10-12'

Sample Number: ST-2

Proj. No.: N4155126 **Date Sampled:** 10-13-15

TRIAXIAL SHEAR TEST REPORT






Terracon, Inc.
Cincinnati, Ohio

Exhibit 7356

Tested By: FCE

Checked By: GS

Exhibit B-30



Client: AEP

Project: ROCKPORT PLANT IMPROVEMENT CERTIFICATION

Source of Sample: B-2

Depth: 10-12'

Sample Number: ST-2

Project No.: N4155126


Exhibit _____

Terracon, Inc.

Tested By: FCE

Checked By: GS

Document Path: P:\GIS - Projects\AEP\mxd\2016-04\04_XSectionLocation.mxd



- Legend**
- Monitoring Well Cluster
 - USWAG Monitoring Well
 - Water Supply Well
 - Cross Section Lines
 - Property Boundary
 - Bottom Ash

Data Sources
 Date of Photography: May-June 2016
 Source of Photography: U.S. Department of Agriculture, National Agriculture Imagery Program (NAIP)



**CROSS SECTION
 LOCATION MAP
 BOTTOM ASH PONDS
 AEP - ROCKPORT, IN**


PROJECT NUMBER: 7382153161

SCALE	1" = 400'
DATE	9/14/2017
DRAWN BY	TMR
APPROVED BY	ALD

**FIG.
4**



2456 Fortune Drive, Suite 100
 Lexington, Kentucky 40509
 Phone: (859) 255-3308



0' 400'
 SCALE: 1"=400'
 VERTICAL EXAGGERATION: 20X



amec foster wheeler
 Environment & Infrastructure, Inc.
 2456 Fortune Drive, Suite 100
 Lexington, Kentucky 40509
 Phone: (859) 255-3308


**BOTTOM ASH PONDS
 AEP - ROCKPORT, INDIANA**

CROSS SECTION A - A'

PROJECT NUMBER: 7382-15-3161

SCALE	1" = 400'
DATE	05/20/2016
DRAWN BY	VM / TMR
APPROVED BY	ALD

FIG. 5



0' 400'
 SCALE: 1"=400'
 VERTICAL EXAGGERATION: 20X



amec foster wheeler
 Environment & Infrastructure, Inc.
 2456 Fortune Drive, Suite 100
 Lexington, Kentucky 40509
 Phone: (859) 255-3308


**BOTTOM ASH PONDS
 AEP - ROCKPORT, INDIANA**

CROSS SECTION B - B'

PROJECT NUMBER: 7362-15-3161

SCALE	1" = 400'
DATE	05/20/2016
DRAWN BY	VM / TMR
APPROVED BY	ALD

**FIG.
 6**



LEGEND:

- | | | | | | |
|--|--|--|--|--|-----------------------------------|
| | USCS Low Plasticity Clay | | USCS Silt | | USCS Clayey Sand |
| | USCS High Plasticity Clay | | USCS Poorly-graded Sand | | USCS Poorly-graded Sand with Silt |
| | USCS Low Plasticity Silty Clay | | USCS Well-graded Sand | | USCS Well-graded Sand with Silt |
| | Fill or Reworked Soil | | Shale | | USCS Well-graded Gravel |
| | Interbedded Poorly Sorted Sand and Sand and Gravel | | Surficial Silt and Clay | | Well Sorted Sand |
| | Screened Interval | | Shale Bedrock | | |
| | | | Water level elevation measured in shallow wells on 17 March 2016 | | |

0' 400'
SCALE: 1"=400'
VERTICAL EXAGGERATION: 20X



Environment & Infrastructure, Inc.
2456 Fortune Drive, Suite 100
Lexington, Kentucky 40509
Phone: (859) 255-3308

BOTTOM ASH PONDS
AEP - ROCKPORT, INDIANA

CROSS SECTION C - C'

PROJECT NUMBER: 7382-15-3161

SCALE	1" = 400'
DATE	05/20/2016
DRAWN BY	VM / TMR
APPROVED BY	ALD

FIG.
7

AMERICAN ELECTRIC POWER SERVICE CORPORATION
AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER **42393125-01**
 COMPANY **INDIANA MICHIGAN POWER COMPANY**
 PROJECT **ROCKPORT PLANT**
 COORDINATES **N 151,510.2 E 514,204.9**
 GROUND ELEVATION **399.9** SYSTEM **State Plane using NAD27/29**

BORING NO. **MW-1604D** DATE **4/27/16** SHEET **1** OF **6**
 BORING START **1/15/16** BORING FINISH **1/15/16**
 PIEZOMETER TYPE _____ WELL TYPE **OW**
 HGT. RISER ABOVE GROUND **2.59** DIA **2.0**
 DEPTH TO TOP OF WELL SCREEN **115.6** BOTTOM **125.15**
 WELL DEVELOPMENT **YES** BACKFILL _____
 FIELD PARTY **ZLR / REB** RIG **D-120**

Water Level, ft	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TIME			
DATE			

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD %	DEPTH IN FEET	GRAPHIC LOG	USCS	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO									
1	SS	0.0	1.5	17-29-28	.6					Surface gravel		
2	SS	1.5	3.0	8-10-10	1.0				CL	Lean silty clay, dark yellowish brown 10YR 4/2, dry to moist, v. stiff @ 3' trace black oxide nodules, some l. brown silt seams, hard		
3	SS	3.0	4.5	10-19-30	1.0							
4	SS	4.5	6.0	5-15-15	1.2		5					
5	SS	5.0	6.5	5-5-9	1.1							
6	SS	7.5	9.0	7-6-9	1.2				CL	Lean silty clay, dark yellowish brown 10YR 4/2, moist, stiff, some medium dark gray N4 silt seams @ 9' wood (~1")		
7	SS	9.0	10.5	6-5-9	1.2		10					
8	SS	10.0	11.5	4-2-3	1.3							
9	SS	12.0	13.5	5-5-7	1.5				CH	Fat clay, olive gray 5Y 4/1, moist, firm, trace black oxide nodules @ 12' stiff @ 13' some moderate yellowish brown 10YR 5/4 silty clay mottled		
10	SS	13.5	15.0	4-5-9	1.5				CH	Fat clay, medium dark gray N4, and silty lean clay, dark yellowish brown 10YR 4/2, mottled, moist, stiff @ 15' tools sunk / 1" spoon driven / material same, pp same, N value inferred @ 15.5' trace black oxide		
11	SS	15.0	16.5	5-6-5	1.0		15					
12	SS	16.5	18.0	2-3-5	1.5							
13	SS	18.0	19.5	3-4-7	1.5				CL ML	Lean silty clay, moderate yellowish brown 10YR 5/4, moist, firm to stiff, w/medium dark gray N4 fat clay seams (~15%)		
14	SS	19.5	21.0	2-3-4	1.4							

TYPE OF CASING USED

	NQ-2 ROCK CORE
	6" x 3.25 HSA
	9" x 6.25 HSA
	HW CASING ADVANCER 4"
	NW CASING 3"
	SW CASING 6"
	AIR HAMMER 8"

Continued Next Page

PIEZOMETER TYPE: PT = OPEN TUBE POROUS TIP, SS = OPEN TUBE SLOTTED SCREEN, G = GEONOR, P = PNEUMATIC
 WELL TYPE: OW = OPEN TUBE SLOTTED SCREEN, GM = GEOMON

RECORDER **AMEC FOSTER WHEELER**

AEP RK BAP CCR COMPLIANCE.GPJ AEP.GDT 4/27/16

AMERICAN ELECTRIC POWER SERVICE CORPORATION
AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER **42393125-01**

COMPANY **INDIANA MICHIGAN POWER COMPANY**

BORING NO. **MW-1604D** DATE **4/27/16** SHEET **2** OF **6**

PROJECT **ROCKPORT PLANT**

BORING START **1/15/16** BORING FINISH **1/15/16**

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD	DEPTH IN FEET	GRAPHIC LOG	USCS	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO			%						
15	SS	21.0	22.5	4-4-4	1.5				ML	Clayey silt, moderate yellowish brown 10YR 5/4, moist, loose		
16	SS	22.5	24.0	2-3-3	1.5				SP	Fine grained sand, moderate yellowish brown 10YR 5/4, moist, loose, poorly graded @ 22.2' ~3" seam clayey silt, moderate yellowish brown 10YR 5/4, moist, loose @ 23.8' ~ 2" silt seam		
17	SS	24.0	25.5	1-1-2	1.0		25		ML	Sandy silt to silty sand, light brown 5YR 5/6, moist, v. loose		
18	SS	25.5	27.0	1-1-2	1.0							
19	SS	27.0	28.5	1-1-5	.83							
20	SS	28.5	30.0	1-5-7	.6				SP	Fine sand, dark yellowish orange 10YR 6/6, moist, loose, poorly graded @ 29' transitioning to moderate yellowish brown 10YR 5/4, moist, sample SS20 spilled		
21	SS	30.0	31.5	5-11-12	.8		30		SP	Fine sand, moderate yellowish brown 10YR 5/4, moist, med. dense, poorly graded @ 31.5' moist, dark yellowish brown 10YR 4/2, loose @ 33' v. loose, water in spoon, wet		
22	SS	31.5	33.0	2-4-3	1.1							
23	SS	33.0	34.5	4-1-3	.8							
24	SS	34.5	36.0	4-3-5	.7		35					
25	SS	36.0	37.5	10-6-9	1.5				SW	Coarse grained sand, dark yellowish brown 10YR 4/2, wet loose, well rounded fine gravel, well graded @ 36.5' v. stiff lean clay moderate yellowish brown 10YR 5/4 seam, higher N value likely due to clay, ~30% clay over last 12" longitudinally @ 38' clay seam @ 40' sand sample mostly washed out clay seam (lean clay, moderate yellowish brown 10YR 5/4, wet, v. stiff) ~50%		
26	SS	37.5	39.0	12-10-12	1.5							
27	SS	39.0	40.5	14-14-16	.6		40					
28	SS	40.5	42.0	5-12-19	1.5				SP	Medium grained sand, moderate yellowish brown 10YR 5/4, wet, dense, poorly graded, well rounded fine gravel @ 42' med dense, well rounded fine gravel		
29	SS	42.0	43.5	8-10-10	1.5							
30	SS	43.5	45.0	14-16-11	1.5							
31	SS	45.0	46.5	3-9-12	1.5		45		SW	Coarse grained sand, moderate yellowish brown 10YR 5/4, wet med. dense, w/well rounded fine gravel (to 1/2"), well graded		

Continued Next Page

AMERICAN ELECTRIC POWER SERVICE CORPORATION
AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER **42393125-01**

COMPANY **INDIANA MICHIGAN POWER COMPANY**

BORING NO. **MW-1604D** DATE **4/27/16** SHEET **3** OF **6**

PROJECT **ROCKPORT PLANT**

BORING START **1/15/16** BORING FINISH **1/15/16**

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD	DEPTH IN FEET	GRAPHIC LOG	USCS	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO			%						
32	SS	46.5	48.0	17-8-9	1.1							
33	SS	48.0	49.5	5-10-11	1.5							
34	SS	49.5	51.0	10-11-12	1.5		50		SP	Fine to med. grained sand, moderate yellowish brown 10YR 5/4, wet, med. dense, poorly graded, w/well rounded fine gravel @ 49.5' trace well rounded fine gravel @ 51' dense, moist @ 55.5' med. dense, transitioning to med. grain @ 57' w/well rounded fine to coarse gravel and rounded sandstone to ~1" @ 60' fully med. grained @ 61.5' w/well rounded fine to coarse gravel and rounded sandstone to 2" @ 63' fine to med. grain, well rounded fine gravel @ 67.5' trace black silt @ 70.5' mostly fine grained, no stone, wet @ 74.8' 1" seam, potential coal or slate, black N1, wet, coarse black N1 silt @ 75' back to fine to med. grain, trace small gravel (~1/4")		
35	SS	51.0	52.5	8-17-18	1.2							
36	SS	52.5	54.0	15-16-16	1.3							
37	SS	54.0	55.5	5-11-19	1.5							
38	SS	55.5	57.0	8-10-12	1.0		55					
39	SS	57.0	58.5	8-12-13	1.1							
40	SS	58.5	60.0	13-9-9	1.1							
41	SS	60.0	61.5	12-9-14	.8		60					
42	SS	61.5	63.0	10-10-11	.8							
43	SS	63.0	64.5	6-10-11	.8							
44	SS	64.5	66.0	7-9-13	1.0		65					
45	SS	66.0	67.5	7-10-16	.7							
46	SS	67.5	69.0	9-10-13	.8							
47	SS	69.0	70.5	8-12-14	.8							
48	SS	70.5	72.0	9-9-12	1.0		70					

AEP RK BAP CCR COMPLIANCE.GPJ AEP.GDT 4/27/16

Continued Next Page

AMERICAN ELECTRIC POWER SERVICE CORPORATION
AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER **42393125-01**

COMPANY **INDIANA MICHIGAN POWER COMPANY**

BORING NO. **MW-1604D** DATE **4/27/16** SHEET **4** OF **6**

PROJECT **ROCKPORT PLANT**

BORING START **1/15/16** BORING FINISH **1/15/16**

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD	DEPTH IN FEET	GRAPHIC LOG	USCS	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO			%						
49	SS	72.0	73.5	7-10-13	1.0							
50	SS	73.5	75.0	6-10-20	1.3							
51	SS	75.0	76.5	11-13-17	1.2		75					
52	SS	76.5	78.0	8-29-47	.8							
53	SS	78.0	79.5	16-23-19	1.0				SP	Coarse sand with gravel (~50%) to 15", moderate yellowish brown 10YR 5/4, moist, v. dense, well graded @ 78' fine gravel, dense		
54	SS	79.5	81.0	10-13-19	1.5		80					
55	SS	81.0	82.5	7-13-18	1.0				SP	Fine grained sand, moderate yellowish brown 10YR 5/4 to dark yellowish brown 10YR 4/2, moist, dense, trace fine gravel, poorly graded @ 81' moist to wet, no gravel @ 82.5' med. dense, trace gravel @ 84' dense, no gravel @ 85.5' med. dense		
56	SS	82.5	84.0	6-12-17	.9							
57	SS	84.0	85.5	10-16-20	.8		85					
58	SS	85.5	87.0	11-11-17	1.2							
59	SS	87.0	88.5	12-15-13	1.3				CL ML	Lean silty clay, dark yellowish brown 10YR 4/2 to medium dark gray N4, moist to wet, v. stiff, w/sand @ 87.2' fine grained sand, moist med. dense, poorly graded		
60	SS	88.5	90.0	11-8-10	1.3				CL ML	Lean silty clay, dark yellowish brown 10YR 4/2 to medium dark gray N4, moist to wet, v. stiff, w/sand		
61	SS	90.0	91.5	7-6-14	1.2		90		SP	Fine grained sand, dark yellowish brown 10YR 4/2, wet, med. dense, poorly graded		
62	SS	91.5	93.0	6-12-9	1.5				CL ML	Lean silty clay, dark yellowish brown 10YR 4/2, moist to wet, v. stiff, w/sand @ 92.3' 5" sand seam (prev material) @ 93.5' 4" sand seam (prev material)		
63	SS	93.0	94.5	7-6-16	1.3							
64	SS	94.5	96.0	9-11-12	1.5		95					
65	SS	96.0	97.5	9-8-9	.8				SP	Fine grained sand, dark yellowish brown 10YR 4/2, wet, med. dense, poorly graded, trace pea gravel		
66	SS	97.5	99.0	13-13-14	.8				SW	Coarse sand and gravel, dark yellowish brown 10YR 4/2, moist to wet, med. dense, well graded, gravel to 1.5"		

AEP RK BAP CCR COMPLIANCE.GPJ AEP.GDT 4/27/16

Continued Next Page

AMERICAN ELECTRIC POWER SERVICE CORPORATION
AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER **42393125-01**

COMPANY **INDIANA MICHIGAN POWER COMPANY**

BORING NO. **MW-1604D** DATE **4/27/16** SHEET **5** OF **6**

PROJECT **ROCKPORT PLANT**

BORING START **1/15/16** BORING FINISH **1/15/16**

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD	DEPTH IN FEET	GRAPHIC LOG	USCS	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO			%						
67	SS	99.0	100.5	13-21-15	1.0		100					
68	SS	100.5	102.0	5-8-12	1.3				SP	Shale, medium dark gray N4, moist, v. stiff to hard, dark yellowish brown 10YR 4/2 w/sand		
69	SS	102.0	103.5	9-13-13	1.1					Fine grained sand, dark yellowish brown 10YR 4/2, v. moist med. dense		
70	SS	103.5	105.0	5-3-8	1.4				SC	Clayey sand, fine grained, dark yellowish brown 10YR 4/2, wet, loose		
71	SS	105.0	106.5	7-11-17	1.4		105					
72	SS	106.5	108.0	10-15-15	1.3				SP	Very fine grain sand, moderate yellowish brown 10YR 5/4, moist to wet, med. dense, poorly graded		
73	SS	108.0	109.5	6-11-18	1.3				SP	Fine to med. grained sand, moderate yellowish brown 10YR 5/4 to medium dark gray N4, moist to wet, med. dense, poorly graded		
74	SS	109.5	111.0	9-17-18	1.2		110			@ 100' dense @ 111' trace rock to 1.5" @ 112.5' no stone @ 114' med. dense @ 115.5' loose, moist to wet @ 117' med. dense @ 118.5' d. grey, w/black silt @ 120' trace gravel to 1/4", dense @ 121.5' med. dense @ 123' wet, dense		
75	SS	111.0	112.5	8-17-24	1.2							
76	SS	112.5	114.0	14-23-23	1.3							
77	SS	114.0	115.5	6-7-10	1.3							
78	SS	115.5	117.0	5-5-5	1.3		115					
79	SS	117.0	118.5	5-5-6	1.4							
80	SS	118.5	120.0	6-9-15	1.3							
81	SS	120.0	121.5	8-15-20	1.5		120					
82	SS	121.5	123.0	8-10-17	1.5							
83	SS	123.0	124.5	7-12-38	1.5							

AEP RK BAP CCR COMPLIANCE.GPJ AEP.GDT 4/27/16

Continued Next Page

AMERICAN ELECTRIC POWER SERVICE CORPORATION
AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING





JOB NUMBER **42393125-01**

COMPANY **INDIANA MICHIGAN POWER COMPANY**

BORING NO. **MW-1604D** DATE **4/27/16** SHEET **6** OF **6**

PROJECT **ROCKPORT PLANT**

BORING START **1/15/16** BORING FINISH **1/15/16**

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD	DEPTH IN FEET	GRAPHIC LOG	USCS	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO			%						
84	SS	124.5	126.0	10-13-35	1.4		125			Coarse sand, medium dark gray N4, moist to wet, dense, with gravel moist to wet graded @ 125.3' 2" coal seam (black, dry, coarse)		
85	SS	126.0	127.5	37-50/2	.5				SW		Shale, medium dark gray N4, dry, hard TOR @ 125.8' Spoon refusal @ 126.6' BT @ 126.6'	

AMERICAN ELECTRIC POWER SERVICE CORPORATION
AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER **42393125-01**
 COMPANY **INDIANA MICHIGAN POWER COMPANY**
 PROJECT **ROCKPORT PLANT**
 COORDINATES **N 151,478.9 E 513,537.1**
 GROUND ELEVATION **400.4** SYSTEM **State Plane using NAD27/29**

BORING NO. **MW-1605D** DATE **4/27/16** SHEET **1** OF **6**
 BORING START **2/3/16** BORING FINISH **2/3/16**
 PIEZOMETER TYPE _____ WELL TYPE **OW**
 HGT. RISER ABOVE GROUND **3.36** DIA **2.0**
 DEPTH TO TOP OF WELL SCREEN **114.6** BOTTOM **124.22**
 WELL DEVELOPMENT **YES** BACKFILL _____
 FIELD PARTY **ZLR / REB** RIG **D-50**

Water Level, ft	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TIME			
DATE			

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD %	DEPTH IN FEET	GRAPHIC LOG	USCS	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO									
1	SS	0.0	1.5	20-13-10	1.25				CL	Gravel = 6 inches		
2	SS	1.5	3.0	5-15-18	1.25				CL	Silty clay, moderate yellowish brown 10R 5/4 and med l. grey N6 mottled, moist, v. stiff @ 1.5' hard @ 3' v. stiff		
3	SS	3.0	4.5	7-9-15	1.41							
4	SS	4.5	6.0	11-12-14	1.5		5					
5	SS	6.0	7.5	4-8-11	1.41							
6	SS	7.5	9.0	3-6-11	1.33				ML	Clayey silt, medium grey N5, moist, med. dense, w/mod. yellowish brown 10R 5/4 silty clay mottled		
7	SS	9.0	10.5	3-4-7	1.41		10		CL	Silty clay, mod. yellowish brown 10R 5/4, moist, stiff, w/mod. grey N5 clayey silt mottled		
8	SS	10.5	12.0	3-4-6	1.5							
9	SS	12.0	13.5	2-2-4	1.5				CH	Fat to lean clay, med. l. grey N6, moist, firm		
10	SS	13.5	15.0	2-2-5	1.41							
11	SS	15.0	16.5	2-4-5	1.5		15		CL ML	Silty clay, mod. reddish brown 10R 4/6 w/mod. l. grey N6 fat clay heavily mottled, moist, firm @ 15' stiff @ 15.5' l" shale fragment, angular @ 18' very silty @ 20' trace to some pale yellowish brown 10YR 6/2 silt		
12	SS	16.5	18.0	3-5-9	1.5							
13	SS	18.0	19.5	3-6-8	1.41							
14	SS	19.5	21.0	3-5-7	1.41							

TYPE OF CASING USED

_____	NQ-2 ROCK CORE
_____	6" x 3.25 HSA
_____	9" x 6.25 HSA
_____	HW CASING ADVANCER 4"
_____	NW CASING 3"
_____	SW CASING 6"
_____	AIR HAMMER 8"

Continued Next Page

PIEZOMETER TYPE: PT = OPEN TUBE POROUS TIP, SS = OPEN TUBE SLOTTED SCREEN, G = GEONOR, P = PNEUMATIC
 WELL TYPE: OW = OPEN TUBE SLOTTED SCREEN, GM = GEOMON

RECORDER **AMEC FOSTER WHEELER**

AEP_RK_BAP_CCR_COMPLIANCE.GPJ_AEP_GDT_4/27/16

AMERICAN ELECTRIC POWER SERVICE CORPORATION
AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER **42393125-01**

COMPANY **INDIANA MICHIGAN POWER COMPANY**

BORING NO. **MW-1605D** DATE **4/27/16** SHEET **2** OF **6**

PROJECT **ROCKPORT PLANT**

BORING START **2/3/16** BORING FINISH **2/3/16**

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD	DEPTH IN FEET	GRAPHIC LOG	USCS	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO			%						
15	SS	21.0	22.5	3-4-7	1.5				ML	Clayey silt, pale yellowish brown 10YR 6/2, moist, med. dense, w/silty clay (prev. material), trace sand		
16	SS	22.5	24.0	4-4-5	1.5				SP	Poorly graded sand, v. fine to fine grained, l. brown 5YR 5/6, moist, loose @ 23.2' 2" clayey silt seam (prev. material)		
17	SS	24.0	25.5	1-1-3	1.5		25		ML	Clayey silt, pale yellowish brown 10YR 6/2, moist to wet, v. loose @ 25' 2" l. brown sand seam (prev. material) @ 26' 2" l. brown sand seam @ 26.4' 15" l. brown sand seam @ 26.8' 1" l. brown sand seam @ 27' loose @ 28' 2" l. brown sand seam		
18	SS	25.5	27.0	1-1-1	1.5				SP	Poorly graded sand, fine grained, l. brown 5YR 5/6, moist, med. dense @ 30' d. yellowish orange 10YR 6/6 @ 31' 3" clayey silt seam (prev. material) @ 32.3' trace fine gravel and black silt @ 32.5' no fine gravel or silt @ 33' moist, loose @ 34.1' 2" clayey silt seam (prev. material) @ 34.5' moist to wet, water in spoon @ 34.9' 2.5' clayey silt seam (prev. material)		
19	SS	27.0	28.5	2-1-4	1.5				SW	Well graded sand, fine grained, l. brown 5YR 5/6, moist to wet, med. dense, w/fine gravel		
20	SS	28.5	30.0	5-6-7	1.33				SW	Well graded sand, coarse grained, grayish black N2, moist to wet, med. dense, trace fine gravel		
21	SS	30.0	31.5	3-5-7	1.25		30		SP	Poorly graded sand, v. fine grained, l. brown 5YR 5/6, moist to wet, med. dense		
22	SS	31.5	33.0	5-7-8	1.5				SP	Well graded sand, fine to med. grained, moderate yellowish brown 10YR 5/4, moist to wet, loose @ 40.5' med. dense @ 41' 1.5" shale seam w/clay		
23	SS	33.0	34.5	3-3-6	1.41				SW	Poorly graded sand, v. fine to fine grained, mod. yellowish brown 10YR 5/4, moist to wet, med. dense		
24	SS	34.5	36.0	2-4-5	1.5		35		SW	Well graded sand, med. grained, mod. reddish brown 10R 4/6, moist to wet, med. dense @ 44' med. to coarse grained		
25	SS	36.0	37.5	2-4-6	1.33				SP	Poorly graded sand, fine grained, mod. yellowish brown 10YR 5/4, moist to wet, med. dense		
26	SS	37.5	39.0	4-3-8	1.5				SW	Well graded sand, med. grained, mod. reddish brown 10R 4/6, moist to wet, med. dense @ 44' med. to coarse grained		
27	SS	39.0	40.5	3-3-5	1.5		40		SP	Poorly graded sand, fine grained, mod. yellowish brown 10YR 5/4, moist to wet, med. dense		
28	SS	40.5	42.0	11-8-10	1.25				SW	Well graded sand, med. grained, mod. reddish brown 10R 4/6, moist to wet, med. dense @ 44' med. to coarse grained		
29	SS	42.0	43.5	4-5-11	1.5				SP	Poorly graded sand, fine grained, mod. yellowish brown 10YR 5/4, moist to wet, med. dense		
30	SS	43.5	45.0	8-9-9	1.16				SW	Well graded sand, med. grained, mod. reddish brown 10R 4/6, moist to wet, med. dense @ 44' med. to coarse grained		
31	SS	45.0	46.5	6-9-14	1.5		45		SP	Poorly graded sand, fine grained, mod. yellowish		

AEP RK BAP CCR COMPLIANCE.GPJ AEP.GDT 4/27/16

Continued Next Page

AMERICAN ELECTRIC POWER SERVICE CORPORATION
AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER **42393125-01**

COMPANY **INDIANA MICHIGAN POWER COMPANY**

BORING NO. **MW-1605D** DATE **4/27/16** SHEET **3** OF **6**

PROJECT **ROCKPORT PLANT**

BORING START **2/3/16** BORING FINISH **2/3/16**

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD	DEPTH IN FEET	GRAPHIC LOG	USCS	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES	
		FROM	TO			%							
32	SS	46.5	48.0	6-8-11	1.5		50		SW	brown 10YR 5/4, moist to wet, mod. dense, some fine gravel			
33	SS	48.0	49.5	6-10-14	1.5				SP	Well graded sand, med. to coarse grained, mod. reddish brown 10R 4/6, moist to wet, mod. dense, trace fine gravel			
34	SS	49.5	51.0	8-12-18	1.33					Poorly graded sand, fine grained, mod. yellowish brown 10YR 5/4, moist to wet, mod. dense, trace fine gravel @ 48' w/fine gravel, trace coarse gravel @ 49.5' no coarse gravel			
35	SS	51.0	52.5	8-11-18	1.41								
36	SS	52.5	54.0	8-9-13	.91		55		SW	Well graded sand, med. to coarse grained, mod. reddish brown 10R 4/6, moist to wet, mod. dense, trace fine gravel			
37	SS	54.0	55.5	11-20-26	1.25				SP	Poorly graded sand, fine grained, mod. yellowish brown 10YR 5/4, moist to wet, mod. dense, trace fine gravel @ 54' no fine gravel, dense @ 57' wet, mod. dense @ 60' dense @ 63' mod. dense			
38	SS	55.5	57.0	10-15-16	1.5								
39	SS	57.0	58.5	6-12-16	1.33								
40	SS	58.5	60.0	7-10-18	1.33		60						
41	SS	60.0	61.5	8-9-12	1.33								
42	SS	61.5	63.0	10-13-19	1.25								
43	SS	63.0	64.5	9-11-18	1.33								
44	SS	64.5	66.0	9-11-15	1.08		65		SW	Well graded sand, med. to coarse grained, mod. yellowish brown 10YR 5/4, moist to wet, mod. dense, trace black silt			
45	SS	66.0	67.5	7-8-13	1.41				SP	Poorly graded sand, fine grained, mod. yellowish brown 10YR 5/4, moist to wet, mod. dense @ 68.5' trace fine gravel, trace coal fragments @ 70' no fine gravel, no coal fragments @ 70.9' trace fine gravel @ 71.6' no fine gravel, wet			
46	SS	67.5	69.0	5-5-8	1.5								
47	SS	69.0	70.5	6-8-12	1.5			70					
48	SS	70.5	72.0	0-12-16	1.5								

AEP RK BAP CCR COMPLIANCE.GPJ_AEP.GDT 4/27/16

Continued Next Page

AMERICAN ELECTRIC POWER SERVICE CORPORATION
AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER **42393125-01**

COMPANY **INDIANA MICHIGAN POWER COMPANY**

BORING NO. **MW-1605D** DATE **4/27/16** SHEET **4** OF **6**

PROJECT **ROCKPORT PLANT**

BORING START **2/3/16** BORING FINISH **2/3/16**

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD	DEPTH IN FEET	GRAPHIC LOG	USCS	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO			%						
49	SS	72.0	73.5	8-8-10	1.25		75		SW	Well graded sand, fine grained d. yellowish brown 10YR 4/2, moist to wet, mod. dense, trace fine gravel @ 73.5' w/fine gravel, trace coarse gravel		
50	SS	73.5	75.0	9-12-17	1.41				SW	Well graded sand, coarse grained, brownish grey 5YR 4/1, moist to wet, mod. dense, w/fine gravel, trace coarse gravel		
51	SS	75.0	76.5	8-7-9	1.5				SP	Poorly graded sand, fine grained, pale yellowish brown 10YR 6/2, wet, dense, trace fine gravel @ 78' mod. dense @ 81' v. fine to fine grained @ 82.5' no fine gravel @ 84' dense @ 85' 2" shale fragment @ 85.2' v. fine grained @ 85.5' 3.5" shale fragment @ 87' fine grained, d. yellowish brown 10YR 4/2 @ 88.5' v. fine grained, mod. dense		
52	SS	76.5	78.0	10-15-25	1.5		80					
53	SS	78.0	79.5	7-13-12	1.33							
54	SS	79.5	81.0	5-7-12	1.5							
55	SS	81.0	82.5	6-12-13	1.5							
56	SS	82.5	84.0	8-10-16	1.41		85					
57	SS	84.0	85.5	10-21-22	1.41							
58	SS	85.5	87.0	14-21-14	.5							
59	SS	87.0	88.5	6-13-25	1.41		90					
60	SS	88.5	90.0	8-9-9	1.16				ML	Clayey silt, med. l. grey N6, moist to wet, mod. dense		
61	SS	90.0	91.5	15-24-7	1.41				SP	Poorly graded sand, fine grained, d. yellowish brown 10YR 4/2, moist, dense		
62	SS	91.5	93.0	7-21-28	1.5		95		ML	Clayey silt, med. l. grey N6, moist to wet, dense		
63	SS	93.0	94.5	14-18-21	1.5				SW	Well graded sand, coarse grained, med. grey N5, w/fine gravel, some coarse gravel		
64	SS	94.5	96.0	12-17-25	1.5		95		ML	Clayey silt, med. l. grey N6, moist to wet, dense		
65	SS	96.0	97.5	20-21-19	1.33				SW	Well graded sand, fine grained, med. grey N5, moist to wet, dense, w/fine gravel @ 98.7' coal fragments		
66	SS	97.5	99.0	13-11-18	1.41							

AEP RK BAP CCR COMPLIANCE.GPJ AEP.GDT 4/27/16

Continued Next Page

AMERICAN ELECTRIC POWER SERVICE CORPORATION
AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER **42393125-01**

COMPANY **INDIANA MICHIGAN POWER COMPANY**

BORING NO. **MW-1605D** DATE **4/27/16** SHEET **5** OF **6**

PROJECT **ROCKPORT PLANT**

BORING START **2/3/16** BORING FINISH **2/3/16**

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD	DEPTH IN FEET	GRAPHIC LOG	USCS	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO			%						
67	SS	99.0	100.5	15-22-28	1.5		100		SP	Poorly graded sand, v. fine to fine grained, pale yellowish brown 10YR 6/2, moist to wet, dense, w/fine gravel @ 100.5' no fine gravel, mod. dense @ 102' v. fine, dense @ 105' mod. dense @ 106' trace coal fragments @ 106.3' no coal fragments @ 109.5' moist @ 111' v. moist to wet @ 112.5' moist to wet, dense @ 113' trace fine gravel, trace coarse gravel @ 113.5' no fine gravel, no coarse gravel		
68	SS	100.5	102.0	8-8-9	1.5							
69	SS	102.0	103.5	10-16-18	1.5							
70	SS	103.5	105.0	9-13-18	1.41							
71	SS	105.0	106.5	8-12-16	1.5							
72	SS	106.5	108.0	6-9-13	1.5							
73	SS	108.0	109.5	7-8-12	1.25							
74	SS	109.5	111.0	6-8-10	1.41							
75	SS	111.0	112.5	5-10-12	1.25		110					
76	SS	112.5	114.0	6-11-27	1.33							
77	SS	114.0	115.5	13-21-13	1.25		115	SW	Well graded sand, med. to coarse grained, med. grey N5, moist to wet, dense, w/fine gravel, some coarse gavel @ 115.5' coarse grained, mod. dense, trace coarse gravel @ 118.5' v. dense			
78	SS	115.5	117.0	7-7-9	1.33							
79	SS	117.0	118.5	9-9-8	1.16							
80	SS	118.5	120.0	12-36-22	1.5							
81	SS	120.0	121.5	10-11-19	1.41		120	SP	Poorly graded sand, v. fine grained, med. l. grey N6, moist to wet, v. dense @ 120' med. dense, sl. moist @ 122' fine grained, w/fine gravel, dense @ 124.5' trace coarse gravel			
82	SS	121.5	123.0	12-20-29	1.5							
83	SS	123.0	124.5	14-16-19	1.5							

AEP RK BAP CCR COMPLIANCE.GPJ AEP.GDT 4/27/16

Continued Next Page

AMERICAN ELECTRIC POWER SERVICE CORPORATION
AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER **42393125-01**

COMPANY **INDIANA MICHIGAN POWER COMPANY**

BORING NO. **MW-1605D** DATE **4/27/16** SHEET **6** OF **6**

PROJECT **ROCKPORT PLANT**

BORING START **2/3/16** BORING FINISH **2/3/16**

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD	DEPTH IN FEET	GRAPHIC LOG	USCS	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO			%						
84	SS	124.5	126.0	18-12-25	1.5		125					
85	SS	126.0	127.5	17-28-50/5	1.5				ML	Clayey silt, l. grey N7, moist, hard, non-durable shale @ 126' flaky, dry to moist Spoon refusal @ 127.4' Auger refusal @127.5' (shale)		
86	SS	127.5	129.0	27-50/2	.66							

AMERICAN ELECTRIC POWER SERVICE CORPORATION
AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER **42393125-01**
 COMPANY **INDIANA MICHIGAN POWER COMPANY**
 PROJECT **ROCKPORT PLANT**
 COORDINATES **N 151,502.1 E 512,881.5**
 GROUND ELEVATION **397.8** SYSTEM **State Plane using NAD27/29**

BORING NO. **MW-1606D** DATE **4/27/16** SHEET **1** OF **5**
 BORING START **2/12/16** BORING FINISH **2/12/16**
 PIEZOMETER TYPE _____ WELL TYPE **OW**
 HGT. RISER ABOVE GROUND **2.91** DIA **2.0**
 DEPTH TO TOP OF WELL SCREEN **100.2** BOTTOM **109.82**
 WELL DEVELOPMENT **YES** BACKFILL _____
 FIELD PARTY **ZLR / REB** RIG **D-120**

Water Level, ft	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
TIME			
DATE			

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD %	DEPTH IN FEET	GRAPHIC LOG	USCS	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO									
1	SS	0.0	1.5	3-5-9	1.5				CL	Crushed stone gravel (limestone)		
2	SS	1.5	3.0	4-7-9	1.5					Lean clay, moderate yellowish brown 10YR 5/4, moist, trace fine grained sand, stiff @ 1.5' as above, trace coarse grain sand and black decomposed organic staining @ 3' trace fine gravel		
3	SS	3.0	4.5	3-4-6	1.3							
4	SS	4.5	6.0	1-2-8	1.3		5					
5	SS	6.0	7.5	5-9-10	1.5				CL	Lean clay, pale yellow brown 10YR 6/2, moist, some light brown oxide staining @ 6.0' yellow brown and brown 10YR 5/4 @ 7.5' pale yellow brown 10YR 6/2, trace fine roots, trace fine grained sand		
6	SS	7.5	9.0	3-6-9	1.5				CL	Lean clay w/sand, dark yellow brown 10YR 4/2, moist, little fine grained sand		
7	SS	9.0	10.5	2-4-5	1.5		10		CL	Lean clay, light bluish gray 5B 7/1, moist, some brown oxide staining, trace coarse grained sand @ 12.5' as above, becomes moderate brown in color 5YR 4/4 @ 13.5' moderate yellow brown 10YR 5/4 and pale yellow brown 10YR 6/2) mottled @ 13.5' - 15' trace fine grained sand, trace fine gravel @ 19.5' mostly 10YR 6/2 in color		
8	SS	10.5	12.0	3-4-6	1.5							
9	SS	12.0	13.5	3-5-9	1.5							
10	SS	13.5	15.0	4-5-7	1.5							
11	SS	15.0	16.5	3-5-6	1.5		15					
12	SS	16.5	18.0	3-4-6	1.5							
13	SS	18.0	19.5	2-5-7	1.5							
14	SS	19.5	21.0	3-3-6	1.5							

TYPE OF CASING USED

	NQ-2 ROCK CORE
	6" x 3.25 HSA
	9" x 6.25 HSA
	HW CASING ADVANCER 4"
	NW CASING 3"
	SW CASING 6"
	AIR HAMMER 8"

Continued Next Page

PIEZOMETER TYPE: PT = OPEN TUBE POROUS TIP, SS = OPEN TUBE SLOTTED SCREEN, G = GEONOR, P = PNEUMATIC
 WELL TYPE: OW = OPEN TUBE SLOTTED SCREEN, GM = GEOMON

RECORDER **AMEC FOSTER WHEELER**

AMERICAN ELECTRIC POWER SERVICE CORPORATION
AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER **42393125-01**

COMPANY **INDIANA MICHIGAN POWER COMPANY**

BORING NO. **MW-1606D** DATE **4/27/16** SHEET **2** OF **5**

PROJECT **ROCKPORT PLANT**

BORING START **2/12/16** BORING FINISH **2/12/16**

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD	DEPTH IN FEET	GRAPHIC LOG	USCS	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO			%						
15	SS	21.0	22.5	3-4-5	1.5							
16	SS	22.5	24.0	2-4-6	1.5			CL ML		Silty clay, pale yellow brown 10YR 6/2, moist, trace to little fine grained sand		
17	SS	24.0	25.5	1-2-5	1.2			SP SM		Poorly graded sand w/silt, pale yellow brown 10YR 6/2, moist, fine to medium grained sand @ 24.9' 3" silt layer		
18	SS	25.5	27.0	2-4-6	1.5		25					
19	SS	27.0	28.5	1-5-9	1.3			CL		Lean clay, moderate yellowish brown 10YR 5/4, moist, few sandy layers <1" thick @ 28.3' SP-SM layer (~3" thick)		
20	SS	28.5	30.0	4-4-5	1.3			SP SM		Poorly graded sand w/silt, dark yellowish orange 10YR 6/6, wet, fine to medium grained sand, little coarse grained sand @ 31.5' trace fine gravel @ 34.5' trace fine gravel		
21	SS	30.0	31.5	5-7-8	1.5		30					
22	SS	31.5	33.0	3-3-4	1.1							
23	SS	33.0	34.5	1-2-5	0							
24	SS	34.5	36.0	3-4-8	.8		35					
25	SS	36.0	37.5	3-5-7	1.0							
26	SS	37.5	39.0	5-6-7	.9			SP		Poorly graded sand, dark yellowish orange 10YR 6/6, wet, fine to medium grained sand, trace to little coarse grained sand @ 37.5' trace gravel		
27	SS	39.0	40.5	4-7-20	1.2			SP SM		Poorly graded sand w/silt, dark yellowish orange 10YR 6/6, wet, fine to medium grained sand, trace coarse grained sand		
28	SS	40.5	42.0	7-7-8	1.1		40	SC		Clayey sand, moderate brown 5YR 3/4, wet, fine to medium grained sand		
29	SS	42.0	43.5	4-6-10	1.0			SP		Poorly graded sand, dark yellowish orange 10YR 6/6, wet, fine to medium grained sand, trace coarse grained sand & fine gravel @ 42.0' - 43.5' increase in coarse grained sand @ 45.2' - 45.5' color change to moderate brown 5YR 4/4 @ 46.5' increase in coarse grained sand, trace wood fragments (tree bark) @ 48' color change to pale yellowish brown 10YR		
30	SS	43.5	45.0	4-5-7	1.0							
31	SS	45.0	46.5	4-6-10	1.2		45					

AEP RK BAP CCR COMPLIANCE.GPJ AEP.GDT 4/27/16

Continued Next Page

AMERICAN ELECTRIC POWER SERVICE CORPORATION
AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER **42393125-01**

COMPANY **INDIANA MICHIGAN POWER COMPANY**

BORING NO. **MW-1606D** DATE **4/27/16** SHEET **3** OF **5**

PROJECT **ROCKPORT PLANT**

BORING START **2/12/16** BORING FINISH **2/12/16**

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD	DEPTH IN FEET	GRAPHIC LOG	USCS	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO			%						
32	SS	46.5	48.0	8-9-11	1.1					6/2, few black decomposed organic layers		
33	SS	48.0	49.5	6-10-13	1.1							
34	SS	49.5	51.0	18-13-13	.9		50		SW SM	Well graded sand w/silt & gravel, wet, pale yellowish brown 10YR 6/2, fine to coarse grained sand, little to some fine gravel, trace coarse gravel		
35	SS	51.0	52.5	7-14-16	1.1				SP SM	Poorly graded sand w/silt, moderate yellowish brown 10YR 5/4, wet, fine to medium grained sand, trace coarse grained sand, few layers of decomposed organics (from 51' - 52.5') @ 54' trace coarse gravel, fines between 5 - 10% @ 55.5' trace fine gravel		
36	SS	52.5	54.0	7-9-15	1.0							
37	SS	54.0	55.5	10-10-14	1.2		55					
38	SS	55.5	57.0	8-10-13	1.2							
39	SS	57.0	58.5	7-9-9	1.3				SW	Well graded sand, med. to coarse grained, dark yellowish brown 10YR 4/2, wet, med. dense, trace fine gravel @ 59' trace coarse gravel		
40	SS	58.5	60.0	4-5-9	1.2		60		SP	Poorly graded sand, fine grained, dusky yellowish brown 10YR 2/2, wet, med. dense, w/fine gravel @ 60.5' 2" shale fragment @ 61.5' dark yellowish brown 10YR 4/2, dense @ 61.8' 2" shale fragment @ 62' some lean clay, pale yellowish brown (prev. material) @ 62.5' no clay, trace fine gravel @ 63' no fine gravel @ 64.5' med. dense @ 65.8' 15" coarse sand seam (prev. material) @ 66' dense @ 67.2' 3" shale seam, med. l. grey N6 @ 67.7' med. grained		
41	SS	60.0	61.5	6-6-9	1.5							
42	SS	61.5	63.0	6-13-21	1.5							
43	SS	63.0	64.5	10-17-31	1.3		65					
44	SS	64.5	66.0	13-13-17	1.4							
45	SS	66.0	67.5	6-14-18	1.5							
46	SS	67.5	69.0	9-14-17	1.5							
47	SS	69.0	70.5	10-20-20	1.1		70		SP	Poorly graded sand, fine gravel, pale yellowish brown 10YR 6.2, wet, dense @ 69' moist to v. moist @ 72' med. dense, fine grained @ 75' dense, d. yellowish brown 10YR 4.2 @ 76.5' med. dense, trace black silt @ 80.6 3" shale plug (responsible for increase in N value (same material)) @ 81.3' 1.5" shale plug, dense		
48	SS	70.5	72.0	10-19-26	1.4							

AEP_RK_BAP_CCR_COMPLIANCE.GPJ_AEP_GDT_4/27/16

Continued Next Page

AMERICAN ELECTRIC POWER SERVICE CORPORATION
AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER **42393125-01**

COMPANY **INDIANA MICHIGAN POWER COMPANY**

BORING NO. **MW-1606D** DATE **4/27/16** SHEET **4** OF **5**

PROJECT **ROCKPORT PLANT**

BORING START **2/12/16** BORING FINISH **2/12/16**

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD	DEPTH IN FEET	GRAPHIC LOG	USCS	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO			%						
49	SS	72.0	73.5	7-10-17	1.3					@ 81.5' no recovery, potential cobble blocking during sampling		
50	SS	73.5	75.0	8-9-13	1.2							
51	SS	75.0	76.5	10-16-25	1.4		75					
52	SS	76.5	78.0	9-10-14	1.4							
53	SS	78.0	79.5	6-9-18	1.5							
54	SS	79.5	81.0	10-17-34	1.5		80					
55	SS	81.0	82.5	31-19-14	1.3							
56	SS	82.5	84.0	10-16-21	1.5			CH	Fat clay, med. l. grey N6, moist, firm			
57	SS	84.0	85.5	9-19-21	1.5		85	SW	Well graded sand, med. grained, dark yellowish brown 10YR 4/2, wet, dense, w/fine gravel @ 83' coal fragment (2" diam., 1" thick) @ 83.6' coal fragment (2" diam, 1" thick)			
58	SS	85.5	87.0	7-15-24	1.3			SP	Poorly graded sand, fine grained, pale yellowish brown 10YR 6/2, wet, dense @ 88.5' trace fine gravel @ 91.5' with fine gravel			
59	SS	87.0	88.5	10-13-20	1.2							
60	SS	88.5	90.0	8-14-23	1.4		90					
61	SS	90.0	91.5	8-13-27	1.3							
62	SS	91.5	93.0	8-7-16	1.5							
63	SS	93.0	94.5	7-9-15	1.5							
64	SS	94.5	96.0	12-12-14	1.5		95	SW	Well graded sand, med. to coarse grained, dark yellowish brown 10YR 4/2, wet, med. dense, w/fine gravel			
								SP				
65	SS	96.0	97.5	3-5-5	1.5			SW	Poorly graded sand, coarse grained, greyish red 5R 4/2, wet, med. dense, trace fine gravel			
								SP				
66	SS	97.5	99.0	5-5-6	1.4			SP	Well graded sand, med. to coarse grained, dark yellowish brown 10YR 4/2, wet, med. dense, w/fine gravel			

AEP RK BAP CCR COMPLIANCE.GPJ AEP.GDT 4/27/16

Continued Next Page

AMERICAN ELECTRIC POWER SERVICE CORPORATION
AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER **42393125-01**

COMPANY **INDIANA MICHIGAN POWER COMPANY**


BORING NO. **MW-1606D** DATE **4/27/16** SHEET **5** OF **5**

PROJECT **ROCKPORT PLANT**


BORING START **2/12/16** BORING FINISH **2/12/16**

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD	DEPTH IN FEET	GRAPHIC LOG	USCS	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO			%						
67	SS	99.0	100.5	4-5-7	1.5		100			Poorly graded sand, coarse grained, greyish red 5R 4/2, wet, med. dense to loose, trace fine gravel Poorly graded sand, fine grained, pale yellowish brown 10YR 6/2, wet, loose @ 97.5' med. dense, fine grained		
68	SS	100.5	102.0	7-7-10	1.4				SP	Poorly graded sand, fine to fine grained, dusky red 5R 3/4, wet, med. dense		
69	SS	102.0	103.5	4-4-6	1.5					@ 102' loose, fine grained, moist		
70	SS	103.5	105.0	5-6-10	1.3					@ 103.5' med. dense @ 105' fine grained @ 106.5' dense		
71	SS	105.0	106.5	4-6-9	1.5		105			@ 108' med. dense, trace fine gravel @ 109' no fine gravel @ 110.6' siltstone fragments to 2.5", moderate brown 5YR 4/4, shiny, angular		
72	SS	106.5	108.0	7-11-20	1.4							
73	SS	108.0	109.5	8-13-15	1.5							
74	SS	109.5	111.0	10-18-11	1.3		110					
75	SS	111.0	112.5	14-50/3				ML	Silt, l. grey N7, moist, med. dense, non-durable shale			
76	SS	112.5	114.0	50/4					@ 111' clayey silt, hard Spoon refusal @ 111.7' Auger refusal @ 112.9 BT @ 112.9'			


Appendix D- Original Design Drawings



SECTION 1-1
RECLAIM, WASTEWATER & BOTTOM ASH PONDS
SCALE 1" = 30'
FOR LOCATIONS SEE DWG NO. 12-30013



SECTION 2-2
NORTH METAL CLEANING WASTE BASIN & E-W BOTTOM ASH PONDS
SCALE 1" = 30'
FOR LOCATIONS SEE DWG NO. 12-30013



DETAIL 8-B
SCALE 1" = 10'
FOR LOCATION SEE DWG NO. 12-30013

SECTION 9-B
SCALE 1" = 10'
FOR LOCATION SEE DWG NO. 12-30013

GENERAL NOTES

- REFERENCE DRAWINGS**
- 12-3003 WASTEWATER & BOTTOM ASH POND AREA, GRADINGS & DRAINAGE
 - 12-30023 SEDIMENTATION BASINS - LOCATION PLAN
 - 12-30024 SEDIMENTATION BASINS - PLANS & DETAILS

NO.	DATE	DESCRIPTION	BY	CHKD.
1	11/01/77	AS PER CIVIL ENGR'S REQUEST, REVISED WEST BOT. ASH POND EL. TO 386.0 WAS 377.0, ADDED NOTE: BOT. EL. 377.0 FOR W.W.22	H/S	H/S
2	09/27/80	RELEASED TO FIELD	WT 3	WT 3

REVISIONS

"THIS DRAWING IS THE PROPERTY OF THE AMERICAN ELECTRIC POWER SERVICE CORP. AND IS LOANED UPON CONDITION THAT IT IS NOT TO BE REPRODUCED OR COPIED, IN WHOLE OR IN PART, OR USED FOR FURNISHING INFORMATION TO ANY PERSON WITHOUT THE WRITTEN CONSENT OF THE AEP SERVICE CORP., OR FOR ANY PURPOSE DETRIMENTAL TO THEIR INTEREST, AND IS TO BE RETURNED UPON REQUEST."

INDIANA & MICHIGAN ELECTRIC CO.
ROCKPORT SITE
ROCKPORT, INDIANA

UNIT No. 1 & 2
WASTEWATER & BOTTOM ASH POND AREA - SECTIONS & DETAILS

DR. NO. 12-30018-1

ARCH.	ELEC.	MECH.	P.D.	STR.	S.F.

LOCAL: AS NOTED
 DESIGNED BY: J.P. SHIMBLE
 CHECKED BY: J.P. SHIMBLE
 DATE: 7/11/77


APPROVED BY: [Signature]
 DATE: 7/11/77

AMERICAN ELECTRIC POWER SERVICE CORP.


12-3002-21 ON "RD"

ROAD / DIKE BASE COURSE DATA				
TOTAL ROAD/DIKE WIDTH (A)	1/2 LANE WIDTH (B)	THICKNESS OF WELL-COMPACTED STONE #53 FOR THE LANE (C)	STABILIZED SHOULDER WIDTH (D)	THICKNESS OF WELL-COMPACTED STONE #53 FOR SHOULDER (E)
20'	6'	6"	4'	3"
30'	15'	12"	0'	0"
40'	15'	12"	5'	6"


GENERAL NOTES
FOR CONTINUATION OF 66" CMP - SEC. G-2
SEE PROFILE SH. 12-3002B.




SECTION C-2
SCALE: 1"=20'




SECTION G-2
SCALE: 1"=20'




TYPICAL SECTION 2-K
FOR REGRADE & REDRESS OF SLOPES ON BOTTOM ASH, WASTEWATER, RECLAIM & CLEARWATER PONDS
SCALE: 1/4"=1'-0"




SECTION C-3
SCALE: 1"=20'




SECTION G-3
SCALE: 1"=20'




SECTION C-4
SCALE: 1"=20'




SECTION G-5
SCALE: 1"=20'




SECTION C-6
SCALE: 1"=20'




SECTION G-6
SCALE: 1"=20'




SECTION C-7
SCALE: 1"=20'



SECTION C-9
SCALE: 1"=20'



DETAIL 9G
SCALE: 3/8"=1'-0"



ELEVATION J9

REFERENCE DRAWINGS
12-3003 WASTEWATER & BOTTOM ASH POND AREA GRADING & DRAINAGE
12-3004 AREA SOUTH OF RECLAIM POND - GRADING, DRAINAGE & TRACK LAYOUT

DATE	NO.	DESCRIPTION	APPD.
4/12/19	8	ADDED TYP DET "G-K" FOR REGRADE & REDRESS OF SLOPES ON BOTTOM ASH, WASTEWATER, RECLAIM & CLEARWATER PONDS.	W/S
2/17/19	7	ADDED SKIMMER SECT G-2 PER R.O.R. ROCK #12-270, R/S. ADDED SECTION G-G.	SF
3/17/19	6	REVISED DESCRIPTION OF STEEL PIPE TO FIBERGLASS DUCT. REVISED PIPE LENGTH DIMS. SEC. C-2, C-3, C-4 & C-6. REVISED PIPE BEND SECTION C-3 & C-9. ADDED LENGTH DIMENSION & REVISED INV. EL. OF 30" STEEL PIPES. REV. LENGTH DIM. OF 66" CMP TO 80". WAS 100".	W/S
4/12/19	4	RELOCATED STRUCT # 6 & #12. REVISED INV. ELEVATIONS AND BASE OF RECLAIM POND. REVISED SECTIONS C-2, C-3, C-4 & C-6. RELOCATED STRUCT # 9 FROM CLEAR WATER POND TO RECLAIM PD & REVISED FLOW.	W/S
4/12/19	3	REVISED SECTION G-2, CHANGED PIPE SIZE 48" TO 36".	W/S
4/12/19	2	ADDED 48" CMP & SLIDE GATES TO SECTIONS C-4 & C-6. RAISED WEST BOTTOM ASH POND EL. TO 385.0 WAS 377.5. RAISED WEST WASTEWATER POND EL. TO 377.5 WAS 375.0. CORRECTED DIM. ON SECTION G-3 TO 12'-0". ON ADDED HOLD STRAPS WITH TURNBUCKLE TO DETAIL 9G.	W/S
4/12/19	1	ADDED STRUCTURE NO. 12 TO SECTION C-2.	W/S

REVISIONS
NOTE: GRADE ELEVATION HAS BEEN ESTABLISHED AS ELEVATION DATUM ADD TO ELEVATIONS SHOWN.

"THIS DRAWING IS THE PROPERTY OF THE AMERICAN ELECTRIC POWER SERVICE CORP. AND IS LOANED UPON CONDITION THAT IT IS NOT TO BE REPRODUCED OR COPIED, IN WHOLE OR IN PART, OR USED FOR FURNISHING INFORMATION TO ANY PERSON WITHOUT THE WRITTEN CONSENT OF THE A.E.P. SERVICE CORP., OR FOR ANY PURPOSE DETRIMENTAL TO THEIR INTEREST, AND IS TO BE RETURNED UPON REQUEST."

INDIANA & MICHIGAN ELECTRIC CO.
ROCKPORT SITE
ROCKPORT, INDIANA

UNIT No. 1 & 2
WASTEWATER & BOTTOM ASH POND AREA - SECTIONS & DETAILS

DR. NO. 12-30027-8

ARCH.	ELEC.	MECH.	STR.

AMERICAN ELECTRIC POWER SERVICE CORP.
2 BROADWAY NEW YORK