

Mountaineer Plant

Notice of Statistically Significant Levels (SSLs) above the Groundwater Protection Standard (GWPS)

CCR Unit – Bottom Ash Pond

As required by 40 CFR 257.95(g), this is a notification that on March 2, 2023 arsenic, lithium, and molybdenum were detected at SSL's above the GWPS's. This notification is being placed in the operating record, as required by 40 CFR 257.105(h)(8). The CCR Unit remains in corrective action.