

## Pirkey Power Plant <u>CN600126767</u> RN100214287

## Notice of Statistically Significant Levels (SSLs) above the Groundwater Protection Standard (GWPS)

## CCR Unit – Flue Gas Desulfurization (FGD) Stackout Area (WMU 023)

As required by 30 TAC 352.951 (d), this is a notification that on September 27, 2021, cobalt and beryllium were detected at SSLs above the GWPSs. This notification serves as the written 14 day notification to the TCEQ Executive Director.

In accordance with 30 TAC 352.951(e), the Pirkey Power Plant intends to make an alternative source demonstration. An alternative source demonstration report will be prepared and certified in accordance with 30 TAC 352.4 and submitted to TCEQ's Executive Director for review within 90 days of the SSL determination.

BOUNDLESS ENERGY"