

# POST CLOSURE PLAN

**CFR 257.104(D)**

Fly Ash Pond  
John E Amos Plant  
Winfield, West Virginia

October, 2017

Prepared for: Appalachian Power Company

Prepared by: Geotechnical Engineering Services

American Electric Power Service Corporation

1 Riverside Plaza

Columbus, OH 43215




Document ID: GERS-17-061

POST CLOSURE PLAN  
CFR 257.104(d)  
FLY ASH POND  
JOHN E AMOS PLANT

**PREPARED BY** John T. Massey-Norton **DATE** 11/21/2017  
John T. Massey-Norton

**REVIEWED BY** Brian Palmer **DATE** 11/21/17  
Brian Palmer, P.E.

**APPROVED BY** Gary F. Zych **DATE** 11/22/2017  
Gary F. Zych, P.E.  
Manager – AEP Geotechnical Engineering



I certify to the best of my knowledge, information, and belief that the information contained in this post closure plan meets the requirements of 40 CFR § 257.104

# TABLE OF CONTENTS

<b>1.0 OBJECTIVE</b> .....	1
<b>2.0 DESCRIPTION OF THE CCR UNIT</b> .....	1
<b>3.0 DESCRIPTION OF POST CLOSURE PLAN 257.104(d)(1)(i)</b> .....	1
3.1 Section 257.104(b)(1).....	1
3.2 Section 257.104(b)(3).....	2
<b>4.0 POST-CLOSURE CONTACT 257.104 (d)(1)(ii)</b> .....	3
<b>5.0 POST-CLOSURE PLANNED USE 257.104 (d)(1)(iii)</b> .....	3

## **1.0 OBJECTIVE**

This report was prepared by AEP- Geotechnical Engineering Services (GES) section to fulfill requirements of CFR 257.104(d) for Post Closure Plan of CCR units.

## **2.0 DESCRIPTION OF THE CCR UNIT**

The John E Amos plant is located in Putnam County, West Virginia. It is owned and operated by Appalachian Power Company (APCO). The facility operates two surface impoundments as part of the operations for storing CCR. This Post Closure Care Plan is for the Fly Ash Pond.

The Fly Ash Pond is a surface impoundment constructed for the permanent disposal of fly ash. The impoundment was formed by constructing the fly ash dam. The dam is a cross valley dam on Scary Creek, a tributary to the Kanawha River. The dam is 220 feet high and has side slopes of 2.5 to 3H:1V on the upstream slope, and 2.0 to 2.5H:1V on the downstream slope.

## **3.0 DESCRIPTION OF POST CLOSURE PLAN 257.104(d)(1)(i)**

*[A description of the monitoring and maintenance activities required in paragraph (b) of this section for the CCR unit, and the frequency at which these activities will be performed.]*

The fly ash pond will be closed by closure in place. The post closure care period will be 30 years.

### **3.1 SECTION 257.104(B)(1)**

*[Maintaining the integrity and effectiveness of the final cover system including making repairs to the final cover as necessary to correct the effects of settlement, subsidence, erosion, or other events, and preventing run-on and run-off from eroding or otherwise damaging the final cover.]*

Inspections are performed for the items noted below. The inspection frequencies will be scheduled monthly, as per West Virginia Department of Environmental Department regulations, to properly detect any issues so that repairs can be performed before significant harm occurs.

- **Embankment**: The entire waste embankment, including top surface and side-slopes, will be inspected for slides, settlement, subsidence, displacement, and cover condition (see below).
- **Soil Dike**: The soil dike will be inspected for slides, displacement, and erosion.
- **Cover**: The final cover will be inspected for erosion and for the condition of the vegetated cover, i.e., gaps in vegetation or presence of undesirable trees or brush. The integrity of the cover drainage system will also be inspected.
- **Final Cover Surface**: The Final Cover surface will be inspected for any ponding of water or flat areas.
- **Surface Drainage System**: The surface drainage system, including channels, culverts, slope drains, etc., will be inspected for erosion, integrity of channel lining, ponding, and accumulated sediment.

Maintenance during the post-closure care period will be performed as discussed below, based upon the facility inspections described above.

- Security Control Devices: Any portions of the roadway barricades which might be damaged will be repaired or replaced as necessary.
- Erosion Damage Repair: Any areas exhibiting erosion will be repaired by replacing and compacting the material in-kind to design grade/specifications, and reseeding the area to the specifications. Applications of additional fertilizer, selective herbicides, rodent control measures, etc. will be implemented as necessary. In the selection of fertilizers and herbicides, ensure their use will not impact the groundwater negatively. Follow-up monitoring of the repaired area will be conducted to ascertain the integrity of the repair.
- Settlement, Subsidence, Displacement: Any areas at the closed site exhibiting evidence of settlement, subsidence, or displacement will be examined to determine the cause of the movement. If backfilling or placing additional fill material is needed to maintain the integrity of the closed structure, it will be performed in accordance with the site/closure specifications, including seeding. If the condition reoccurs or persists, or if the severity of the condition initially is judged to warrant it, a detailed investigation of the cause will be performed and remedial action will be performed. Similarly, any areas of the soil dike exhibiting sliding, displacement, or seepage will be investigated. Repairs will be made as necessary. Follow-up monitoring of the area will be performed to ascertain that the problem has been corrected.
- Closure Cap Surface: Any areas that show signs of ponding water or flat contours will be examined and rectified.
- Surface Water Drainage System: The channel linings are designed to withstand the design velocities. Maintenance of the surface water drainage system will consist of removing sediment and/or undesirable vegetation from the surface water runoff control system (channels and culverts) as required. Eroded areas will be repaired by back-filling and reseeding according to the specifications. Damage to culverts will be repaired; structure replacement will be performed if needed.
- Seepage: The dam will be inspected for any seepage. Seepage from the dam will be inspected, investigated, monitored, or repaired as deemed necessary.

### 3.2 SECTION 257.104(B)(3)

*[Maintaining the groundwater monitoring system and monitoring the groundwater in accordance with the requirements of §§257.90 through 257.98.]*

The groundwater monitoring system will be inspected for the general integrity of the wells, well casings and well protective casings. Any damaged portions of the monitoring wells and/or their protective casings will be replaced in-kind.

Monitoring the groundwater will be in accordance with the groundwater monitoring plan for this facility and in accordance with the requirements of §§257.90 through 257.98.

#### **4.0 POST-CLOSURE CONTACT 257.104 (d)(1)(ii)**

***[The name, address, telephone number and email address of the person or office to contact about the facility during the post-closure care period.]***

The name, address, and telephone number of the person to contact about the Facility during the post-closure period shall be provided upon notice of closure.

#### **5.0 POST-CLOSURE PLANNED USE 257.104 (d)(1)(iii)**

***[A description of the planned uses of the property during the post-closure period. Post-closure use of the property shall not disturb the integrity of the final cover, liner(s), or any other component of the containment system, or the function of the monitoring systems unless necessary to comply with the requirements in this subpart...]***

The post-closure use of the property will be undisturbed vacant land space. The only activities occurring on the closed CCR unit will be related to the Post-Closure care activities.