

John Amos Plant

Notice of Assessment Monitoring Program Establishment

Bottom Ash Pond

On January 15, 2018, it was determined that Amos Plant's Bottom Ash Pond had statistically significant increases over background for Calcium, Chloride, Sulfate, and Total Dissolved Solids (TDS). An alternative source demonstration was not successful within the 90 day period as allowed for in 257.94(e)(2) prompting the initiation of an assessment monitoring program, which was established on April 13, 2018. Therefore this notice is being placed in the operating record in accordance with the requirement of 257.94(e)(3).