

Northeastern Power Station

Notice of Establishing Assessment Monitoring Program (EAP)

Bottom Ash Pond

On January 22, 2018, it was determined that Northeastern's Bottom Ash Pond had statistically significant increases over background for Boron, Chloride, Fluoride, pH, Sulfate, and Total Dissolved Solids (TDS). An alternative source demonstration was not successful within the 90 day period as allowed for in 257.94(e)(2) and 252:517-9-5(e)(2) prompting the initiation of an assessment monitoring program, which was established on April 13, 2018. Therefore this notice is being placed in the operating record in accordance with the requirement of 257.94(e)(3) and 252:517-9-5(e)(3).