

Pirkey Plant

Notice of Assessment Monitoring Program Establishment

FGD Stackout Area

On January 3, 2018, it was determined that Pirkey Plant's FGD Stackout Area had statistically significant increases over background for Boron, Chloride, and Sulfate. An alternative source demonstration was not successful within the 90 day period as allowed for in 257.94(e)(2) prompting the initiation of an assessment monitoring program, which was established on April 3, 2018. Therefore this notice is being placed in the operating record in accordance with the requirement of 257.94(e)(3).