

Rockport Plant Bottom Ash Pond

Notice of Assessment Monitoring Initiation

On January 15, 2018, it was determined that the Rockport Plant's Bottom Ash Pond Complex had statistically significant increases over background for the Appendix III parameters of boron, chloride, fluoride, pH, TDS, and sulfate. An alternative source demonstration was not successful within the 90 day period as allowed for in 257.94(e)(2). Therefore, an assessment monitoring program was established at Rockport's bottom ash pond complex on April 15, 2018 and this notice is being placed in Rockport's operating record in accordance with the requirement in 257.94 (e)(3).