

Welsh Power Plant

Notice of Establishing Assessment Monitoring Program (EAP)

Landfill

On January 18, 2018, it was determined that Welsh's Landfill had statistically significant increases over background for Boron, Sulfate, and Total Dissolved Solids (TDS). An alternative source demonstration was not successful within the 90 day period as allowed for in 257.94(e)(2) prompting the initiation of an assessment monitoring program, which was established on April 13, 2018. Therefore this notice is being placed in the operating record in accordance with the requirement of 257.94(e)(3).