

Welsh Power Plant

Notice of Establishing Assessment Monitoring Program (EAP)

Primary Bottom Ash Pond

On January 04, 2018, it was determined that Welsh's Primary Bottom Ash Pond had statistically significant increases over background for Boron. An alternative source demonstration was not successful within the 90 day period as allowed for in 257.94(e)(2) prompting the initiation of an assessment monitoring program, which was established on April 13, 2018. Therefore this notice is being placed in the operating record in accordance with the requirement of 257.94(e)(3).