



An **AEP** Company

BOUNDLESS ENERGY™

## Pirkey Plant

### Notice of Statistically Significant Level (SSL) above the Groundwater Protection Standard (GWPS)

#### CCR Unit – Flue Gas Desulfurization (FGD) Stackout Area

As required by 40 CFR 257.95(g), this is a notification that on October 2, 2020, cobalt and beryllium were detected at SSLs above the GWPSs. This notification is being placed in the plant's operating record as required by 40 CFR 257.105(h)(8).

BOUNDLESS ENERGY™