

Mountaineer Plant

Notice of Statistically Significant Levels (SSLs) above the Groundwater Protection Standard (GWPS)

CCR Unit – Bottom Ash Pond

As required by 40 CFR 257.95(g), this is a notification that on September 19, 2021 lithium was detected at SSL's above the GWPS's. This notification is being placed in the operating record, as required by 40 CRF 257.105(h)(8).