



An **AEP** Company

BOUNDLESS ENERGY™

Pirkey Power Plant

CN600126767

RN100214287

Notice of Statistically Significant Levels (SSLs) above the
Groundwater Protection Standard (GWPS)

CCR Unit – East Bottom Ash Pond (WMU 005)

As required by 30 TAC 352.951 (d), this is a notification that on March 19, 2022, lithium and cobalt were detected at SSLs above the GWPSs. This notification serves as the written 14 day notification to the TCEQ Executive Director.

In accordance with 30 TAC 352.951(e), the Pirkey Power Plant intends to make an alternative source demonstration. An alternative source demonstration report will be prepared and certified in accordance with 30 TAC 352.4 and submitted to TCEQ's Executive Director for review within 90 days of the SSL determination.

BOUNDLESS ENERGY™